

Designation: A 861 - 04

Standard Specification for High-Silicon Iron Pipe and Fittings¹

This standard is issued under the fixed designation A 861; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

Sanitary T Branches

Hub Plain End Pipe

Straight Tees

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

- 1.1 This specification covers high-silicon iron pipe and pipe fittings intended for corrosion-resistant service for both above-and below-grade construction.
- 1.2 Pipe and pipe fittings shall be the no-hub (MJ) or the hub and plain end design.
- 1.3 Pipe and pipe fittings shall be of the sizes specified in Table 1 and Table 2 and Figs. 1-71 or other sizes that shall be permitted to conform to the requirements given herein.

1.3.1 *Pipe*:

1.3.1.1 *No-hub (MJ) (Fig. 1)*:

Size (in.)	Length (ft)
11/2	7
2	7
3	7
4	7

1.3.1.2 *Hub/Plain End (Fig. 35)*:

Size (in.)	Length (ft)
2	7
3	7
4	7
6	7
8	7
10	5
12	5
15	5

1.3.2 *Fitting (No-hub) (MJ)*:

	Figs.
Quarter Bends	2
Sixth Bends	3
Return Bends	4
Double-Branch Quarter Bend	5
Eighth Bends	6
Sixteenth Bends	7
Long-Sweep Quarter Bends	8
Sanitary Y Branches	9
Double-Branch Sanitary Y	10
Sanitary Combination Y and 1/8 Bend	11
Double-Branch Sanitary Combination Y and 1/8 Bend	12

¹ This specification is under the jurisdiction of ASTM Committee A04 on Iron Castings and is the direct responsibility of Subcommittee A04.12 on Pipes and Tubes.

Double Branch Sanitary T	14
Sanitary Running Traps	15
Sanitary P Traps	16
Swivel Trap P-Style Short	17
Swivel Trap P-Style Long	18
Swivel Trap S-Style Long	19
Centrifugal Drum Trap P Swivel Type	20
Centrifugal Drum Trap S Swivel Type	21
Combination Cleanout and Test Tees	22
Coupling	23
Pipe Plugs	24
Cleanout Plugs	25
No-hub (MJ) Adapter	26
Reducers—Increasers	27
Sink Outlet	28
Sink Overflows	29
Threaded Adapters	30
Trap Cleanout Details	31
No-hub (MJ) Adapter	32
(MJ) (No-hub) to Lead Adapter	33
Floor Drains	34

13

Figs.

35

36

1.3.3 Fitting (Hub/Plain End):

Straight rees	30
Sanitary T Branches	37
Sanitary Y Branches	38
Double-Branch Sanitary Tee	39
Double-Branch Sanitary Y	40
Double-Branch Sanitary Combination Y and 1/8 Bend (T-	Y) 41
Short-Sweep Quarter Bends	42
Long-Sweep Quarter Bends	43
Sanitary Combination Y and 1/8 Bend (T-Y)	44
Quarter Bends	45
Sixth Bends	46
Eighth Bends	47
Sixteenth Bends	48
Sanitary Increasers	49
Hub Strainers	50
Sanitary Reducers	51
Double Hubs	52
Pipe Plugs	53
Cleanout Plugs	54
Adapter—Plain end to Split Flange	55
Adapter—Hub to-Split Flange	56
Combination Cleanout and Test Tees	57
Insertable Joints	58
Backwater Valves	59
Sanitary P Traps	60
Sanitary S Traps	61
Sanitary Running Traps	62
Floor Drains	63, 64, 65
Floor Drains	66

Current edition approved May 1, 2004. Published May 2004. Originally approved in 1986. Last previous edition approved in 2002 as A 861-02.



Floor Drains/Installation—Funnel Attachment	67, 68
Overflow	69
Sink Outlet	70
Detailed Cross Section of Cleanout	71
Chemical Composition	Table 3
Transverse Bend Test Minimum Requirements	Table 4

2. Referenced Documents

2.1 ASTM Standards: ²

A 518/A 518M Specification for Corrosion-Resistant High-Silicon Iron Castings

E 350 Test Methods for Chemical Analysis of Carbon Steel, Low-Alloy Steel, Silicon Electrical Steel, Ingot Iron, and Wrought Iron

E 351 Test Methods for Chemical Analysis of Cast Iron—All Types

2.2 Other Standards:

Uniform Classification Rules³

National Motor Freight Classification³

3. Terminology

- 3.1 Definitions of Terms Specific to This Standard:
- 3.1.1 *hubless*—a pipe or fitting without a hub, sometimes called no-hub, joined by a coupling.
 - 3.1.2 MJ—an abbreviation for mechanical joint.
- 3.1.3 *no-hub*—a pipe or fitting without a hub, sometimes described as hubless joined by a coupling.

4. Ordering Information

- 4.1 Ordering for material under this specification shall include as a minimum the following information:
- 4.1.1 ASTM designation, grade (see Table 3) and year of issue.
- 4.1.2 Description of the casting by figure number (see Figs. 1 through 71) or by manufacturer's drawings or catalog number, or both.
- 4.1.3 Length, diameter, and type of pipe and size and shape of fittings.
 - 4.1.4 Quantity.
 - 4.1.5 Certification requirements.
 - 4.1.6 Special packaging requirements (see Section 14).
 - 4.1.7 Supplemental requirements desired, if any.

5. Materials and Manufacture

- 5.1 The castings shall be produced by any established commercial practice applicable to high-silicon iron.
- 5.2 The castings shall be true to pattern, reasonably smooth, and free from defects that would make the castings unfit for the use for which they are intended.

6. Chemical Composition

6.1 An analysis of each heat shall be made by the manufacturer from a test sample that is representative of the heat and

that is taken during the heat. A heat shall consist of all castings poured from a furnace or crucible melt without recharging new metal into the furnace. The chemical composition thus determined shall conform to the requirements for the grade selected specified in Table 3.

- 6.2 A product analysis shall be permitted to be made by the purchaser from material representing the heat. The chemical composition thus determined shall meet the requirements specified in Table 3 or shall be subject to rejection by the purchaser.
- 6.3 Spectrometric or other instrumental methods and wet laboratory methods are acceptable for routine control determinations. Any method employed shall give essentially the same results as reference methods listed in Test Methods E 350. (For selected detailed methods of analysis, see Specification A 518, paragraph 6.4).

7. Heat Treatment

- 7.1 All centrifugally cast high-silicon iron pipe shall be supplied in the as-cast condition. All other pipe and fittings shall be supplied in the stress-relieved condition.
 - 7.2 Stress relieving shall be performed as follows:
- 7.2.1 Hold the casting at 1650°F (870°C) minimum for 2 h plus an additional hour per inch of section thickness for castings over 2 in. in thickness.
- 7.2.2 Cool the castings to $400^{\circ}F$ ($205^{\circ}C$) maximum at a rate not to exceed $100^{\circ}F$ ($55^{\circ}C$)/15 min.
- 7.2.3 From 400°F (205°C) to ambient, the castings shall be permitted to be cooled in still, ambient air.

8. Joints

- 8.1 Acid-proof joints for hub/plain-end pipe shall require the use of an acid-proof rope packing.
- 8.2 No-hub pipe and fittings shall require a special acid resistant mechanical joint (MJ) coupling. One satisfactory coupling consists of an inner PTFE sleeve surrounded by neoprene. The two-bolt coupling is made of 300 series stainless steel.
- 8.3 High-silicon iron pipe can be cut with either manual or hydraulic snap cutters. Field cuts shall be permitted to be readily used with mechanical joint couplings to provide acceptable leak-proof joints.

9. Dimensions and Permissible Variations

- 9.1 *Pipe*
- 9.1.1 Hub/plain-end pipe shall have a hub at one end and a plain end at the other and shall be cast in one piece (see Fig. 35).
- 9.1.2 Individual length of hub/plain-end pipe shall be either 7 or 5 ft nominal laying lengths as shown in Fig. 35.
- 9.1.3 Any deflections in the barrel of a single length of pipe shall not exceed $\frac{3}{16}$ in.
- 9.1.4 No-hub pipe shall be cast in a single piece and conform to nominal dimensions shown in Fig. 1.
- 9.1.5 No dimension of hub/plain-end pipe shall exceed the tolerances specified in Table 1.
- 9.2 Fittings—All fittings shall conform to the nominal dimensions specified in applicable figures and be within the

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American Trucking Assoc., Traffic Dept., 2200 Mill Rd., Alexandria, VA 22314.

tolerances specified in Table 2 for fittings listed in Figs. 2 through 34 or in Table 1 for fittings listed in Figs. 36 through 39

10. Inspection

- 10.1 Inspection and Test by the Manufacturer—Pipe and fittings shall be inspected by the manufacturer prior to shipment. Inspection by the manufacturer shall include all tests as specified herein. All tests and inspection with the exception of product analysis shall be made at the place of manufacture unless otherwise agreed upon.
- 10.2 Inspection and Test by the Purchaser—The manufacturer shall afford the purchaser's inspector all reasonable facilities necessary to satisfy that the material is being produced and furnished in accordance with this specification. Foundry inspection by the purchaser shall not interfere unnecessarily with the manufacturer's operations.

11. Rejection and Rehearing

11.1 Material that shows unacceptable discontinuities as determined by the acceptance standards specified in the order, subsequent to its acceptance at the manufacturer's works, shall be rejected and the manufacturer shall be notified within 30 days unless otherwise agreed upon.

12. Certification

12.1 Upon request of the purchaser, the manufacturer shall certify that his product conforms to the requirements of this specification. The results of tests shall be furnished to the purchaser upon request as mutually agreed upon.

13. Product Marking

- 13.1 Each length of pipe and fitting shall be identified by the manufacturer's name or identification mark. Marking shall be as not to impair the usefulness of the part.
- 13.2 Samples that represent rejected material shall be preserved for a minimum of 2 weeks from the date of transmission of the rejection report. In case of dissatisfaction with the results of the tests, the manufacturer shall be permitted to make claim for a rehearing within that time.

14. Packaging

14.1 Unless otherwise specified, the material shall be packaged in accordance with the supplier's standard practice and acceptable to the carrier at the lowest rates. Containers and packing shall comply with Uniform Classification Rules or National Motor Freight Classification Rules.

15. Keywords

15.1 corrosion resistant; fittings; high-silicon iron; hubless; hub/plain-end; no-hub; plain-end

SUPPLEMENTARY REQUIREMENTS

The following supplementary requirements are for use when desired by the purchaser. They shall not apply unless specified in the order, in which event the specified tests shall be made by the manufacturer before shipment of the castings.

S1. Transverse Bend Tests

- S1.1 Transverse bend properties shall be determined from material representing each heat and shall meet the requirements shown in Table S1.1. Properties thus measured shall be considered representative of the quality of the high-silicon iron but may not represent properties in the actual castings.
- S1.2 Transverse bend tests shall be conducted in accordance with the manufacturer's established test procedure for transverse bend test including the following:
- S1.2.1 The specimens shall not be machined or ground and shall conform to the dimensions in Fig. 72.
- S1.2.2 The specimens shall be cast in patterns in accordance with Fig. 73.
- S1.2.3 The specimens shall be heat treated in accordance with Section 7.
- S1.2.4 The actual breaking load shall be reported. The requirements of Table 2 allow for any deviation due to variations in test bar diameter. The deflection at fracture shall also be reported without correction.
- \$1.2.5 The rate of loading shall produce 0.025-in. (0.64-mm) deflection in 50 to 70 s. Continue loading at this rate until the specimen fractures.

TABLE S1.1 Transverse Bend Test Minimum Requirements^A

 Load at Center, min, lbf (N)
 930 (4090)

 Deflection at Center, min, in. (mm)
 0.026 (0.66)

ATest bars are to be tested on supports 12 in. (305 mm) apart.

S2. Hydrostatic Testing

S2.1 Hydrostatic tests at 40 psi, minimum, shall be conducted on all castings specified in the order. Any leak revealed by this test shall be cause for rejection for the individual piece. A leak shall include any evidence of moisture on the outside diameter of the part established to have occurred due to through-wall leakage.

TABLE 1 Tolerances for High-Silicon Iron Hub/Plain-End Pipe

Note 1—1 in. = 25.4 mm.

Size, in.	Wall Thickness, in.	ID Tolerance, in.	OD Tolerance, in.
2	±1/32	±1/32	± 1/ ₃₂
3	±1/32	±1/32	± 1/ ₃₂
4	±1/32	±1/32	± 1/ ₃₂
6	±1/32	±1/32	±3/64
8	±1/32	±1/8	±1/8
10	±1/8	±1/8	±1/8
12	±1/8	±1/8	±1/8
15	±1/8	±1/8	±1/8


TABLE 2 Tolerances for High-Silicon Iron Fittings

Note 1—1 in. = 25.4 mm.

Size, in.	ID Tolerance, in.	OD Tolerance, in.	Stop Lug Depth Tolerance, in.
11/2	±1/ ₁₆	±1/16	±1/16
$1\frac{1}{2} \times 1\frac{1}{2}$	±1/16	±1/16	±1/16
2	±1/16	±1/16	±1/16
2 × 1½	±1/16	±1/16	±1/16
2×2	±1/16	±1/16	±1/16
3	±1/16	±1/16	±1/16
$3 \times 1\frac{1}{2}$	±1/ ₁₆	±1/16	±1/16
3×2	±1/16	±1/16	±1/16
3×3	±1/16	±1/16	±1/16
4	±1/16	±1/16	±1/16
$4 \times 1\frac{1}{2}$	±1/16	±1/16	±1/16
4×2	±1/16	±1/16	±1/16
4×3	±1/16	±1/16	±1/16
4 × 4	±1/ ₁₆	±1/16	±1/16


TABLE 3 Chemical Composition

Element	Composition, Weight %		
Element	Grade 1	Grade 2	
Carbon	0.65-1.10	0.75-1.15	
Manganese	1.50 max	1.50 max	
Silicon	14.20-14.75	14.20-14.75	
Chromium	0.50 max	3.25-5.00	
Molybdenum	0.50 max	0.40-0.60	
Copper	0.50 max	0.50 max	



Size, in.	J, in.	F, in.	t, in.
11/2	23/16 (2.19)	84	5/16
2	211/16 (2.69)	84	5/16
3	349/64 (3.77)	84	5/16
4	449/64 (4.77)	84	5/16

Note 1-1 in. = 25.4 mm. FIG. 1 No-Hub Pipe (MJ)



Size, in.	D, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	41/4	11/2	23/16 (2.19)	11/32
2	41/2	2	25/8 (2.62)	11/32
$2 \times 1\frac{1}{2}$	$4\frac{3}{16} \times 4\frac{1}{2}$	$2 \times 1\frac{1}{2}$	$2\frac{5}{8} \times 2\frac{3}{16}$	11/32
3	5	3	3¾ (3.75)	11/32
4	51/2	4	4¾ (4.75)	11/32

Note 1—1 in. = 25.4 mm. FIG. 2 Quarter Bends







TABLE 3 Continued					
Size, in. D, in. ID, in. OD, in. Stop Lug Depth (P),					
11/2	3	11/2	23/16	11/32	
2	31/4	2	25/8	11/32	
3	31/2	3	33/4	11/32	
4	33/4	4	43/4	11/32	


Note 1—1 in. = 25.4 mm. FIG. 3 Sixth Bends



Size, in.	C, in.	D, in.	F, in.	R, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	4	2	53/32	2	11/2	23/16	11/32
2	43/4	2	511/16	23/8	2	25/8	11/32

Note 1-1 in. = 25.4 mm.


FIG. 4 Return Bends



Size, in.	D, in.	E, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	37/8	3¾	11/2	23/16	11/32

Note 1-1 in. = 25.4 mm.

FIG. 5 Double-Branch Quarter Bend



Size, in.	D, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	21/2	11/2	23/16	11/32
2	23/4	2	25/8	11/32
3	3	3	33/4	11/32
4	31/4	4	43/4	11/32


Note 1—1 in. = 25.4 mm. FIG. 6 Eight Bends





	TA	ABLE 3 Conti	nued	
Size, in.	D, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	2	11/2	23/16	11/32
2	21/8	2	25/8	11/32
3	21/4	3	33/4	11/32
4	23/8	4	43/4	11/32

Note 1—1 in. = 25.4 mm. FIG. 7 Sixteenth Bends



 Size, in.
 D, in.
 ID, in.
 OD, in.
 Stop Lug Depth (P), in.

 1½
 9¼
 1½
 2¾6
 1⅓2

 2
 9½
 2
 2½
 1⅓32

 3
 10
 3
 3¾4
 1⅓32

 4
 10½
 4
 4¾4
 1⅓32

FIG. 8 Long-Sweep Quarter Bends








			TABLE 3 Contin	nued		
Size, in.	D, in.	F, in.	G, in.	ID, in	OD, in.	Stop Lug Depth (P), in.
1/2 × 11/2	45/8	61/2	17/8	1½ × 1½	2 ³ / ₁₆ × 2 ³ / ₁₆	11/32
2 × 1½	47/8	61/2	15/8	2 × 1½	$25/8 \times 23/16$	11/32
2×2	45/8	63/8	2	2×2	$25/8 \times 25/8$	11/32
3 × 1½	55/8	61/2	11/4	3 × 1½	$3\frac{3}{4} \times 2\frac{3}{16}$	11/32
3×2	57/8	71/8	11/2	3×2	$3\frac{3}{4} \times 2\frac{5}{8}$	11/32
3×3	63/8	85/8	21/4	3 imes 3	$3\frac{3}{4} \times 3\frac{3}{4}$	11/32
4 × 1½	65/8	71/2	13/8	$4 \times 1\frac{1}{2}$	$4\frac{3}{4} \times 2\frac{3}{16}$	11/32
4×2	65/8	71/2	13/8	4 × 2	$4\frac{3}{4} \times 2\frac{5}{8}$	11/32
4×3	71/8	83/4	13/4	4×3	$4\frac{3}{4} \times 3\frac{3}{4}$	11/32
4×4	75/8	101/4	25/8	4×4	$4\frac{3}{4} \times 4\frac{3}{4}$	11/32

Note 1—1 in. = 25.4 mm. FIG. 9 Sanitary Y Branches



Size, in.	D, in.	F, in.	G, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
1½ × 1½	45/8	61/2	17/8	1½ × 1½	23/16 × 23/16	11/32
$2 \times 1\frac{1}{2}$	47/8	61/2	15/8	$2 \times 1\frac{1}{2}$	$25/8 \times 23/16$	11/32
2×2	45/8	63/8	2	2×2	$2\frac{5}{8} \times 2\frac{5}{8}$	11/32
$3 \times 1\frac{1}{2}$	55/8	61/2	11/4	$3 \times 1\frac{1}{2}$	$3\frac{3}{4} \times 2\frac{3}{16}$	11/32
3×2	57/8	71/8	11/2	3×2	$3\frac{4}{4} \times 2\frac{5}{8}$	11/32
3×3	63/8	85/8	21/4	3×3	$3\frac{3}{4} \times 3\frac{3}{4}$	11/32
4×2	65/8	71/2	13/8	4×2	$4\frac{3}{4} \times 2\frac{5}{8}$	11/32
4×3	71/8	83/4	13/4	4×3	$4\frac{3}{4} \times 3\frac{3}{4}$	11/32
4×4	7 5/8	101/4	25/8	4×4	$4\frac{3}{4} \times 4\frac{3}{4}$	11/32

 $\label{eq:Note_1} Note \ 1\text{---}1 \ in. = 25.4 \ mm.$ FIG. 10 Double-Branch Sanitary Y



Size, in.	D, in.	E, in.	F, in.	G, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
1½ × 1½	43/4	53/8	61/2	17/8	½ × 1½	2 ³ / ₁₆ × 2 ³ / ₁₆	11/32
2 × 1½	43/4	53/4	61/2	15/8	$2 \times 1\frac{1}{2}$	$25/8 \times 23/16$	11/32
2×2	5	57/8	65/8	17/8	2×2	$25/8 \times 25/8$	11/32
$3 \times 1\frac{1}{2}$	4	51/4	61/2	15/8	$3 \times 1\frac{1}{2}$	$3\frac{3}{4} \times 2\frac{3}{16}$	11/32
3×2	5	61/4	71/8	11/2	3×2	$3\frac{3}{4} \times 2\frac{5}{8}$	11/32
3×3	61/4	7	81/2	21/4	3×3	$3\frac{3}{4} \times 3\frac{3}{4}$	11/32
$4 \times 1\frac{1}{2}$	45/16	61/8	65/8	13/8	$4 \times 1\frac{1}{2}$	$4\frac{3}{4} \times 2\frac{3}{16}$	11/32
4×2	5	63/8	73/8	13/8	4×2	$4\frac{3}{4} \times 2\frac{5}{8}$	11/32
4×3	6	71/4	83/4	13/4	4× 3	$4\frac{3}{4} \times 3\frac{3}{4}$	11/32
4 × 4	7 3/8	8	101/4	25/8	4× 4	$4\frac{3}{4} \times 4\frac{3}{4}$	11/32







			TABLE	3 C	ontinued		
Size, in.	D, in.	E, in.	F, in.	G, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
1½ × 1½	43/4	53/8	61/2	7 7/8	1½ × 1½	2 ³ / ₁₆ × 2 ³ / ₁₆	11/32
$2 \times 1\frac{1}{2}$	43/4	53/4	61/2	15/8	$2 \times 1\frac{1}{2}$	$25/8 \times 23/16$	11/32
2×2	5	57/8	65/8	15/8	2×2	$2\frac{5}{8} \times 2\frac{5}{8}$	11/32
$3 \times 1\frac{1}{2}$	41/4	51/4	61/2	15/8	$3 \times 1\frac{1}{2}$	$3\frac{3}{4} \times 2\frac{3}{16}$	11/32
3×2	5	61/4	71/8	11/2	3×2	$3\frac{3}{4} \times 2\frac{5}{8}$	11/32
3×3	61/4	7	81/2	21/4	3×3	$3\frac{3}{4} \times 3\frac{3}{4}$	11/32
4×2	5	63/8	73/8	13/8	4×2	$4\frac{3}{4} \times 2\frac{5}{8}$	11/32
4×3	6	71/4	83/4	13/4	4×3	$4\frac{3}{4} \times 3\frac{3}{4}$	11/32
4×4	7 3/8	8	101/4	25/8	4×4	$4\frac{3}{4} \times 4\frac{3}{4}$	11/32

Note 1—1 in. = 25.4 mm. FIG. 12 Double-Branch Sanitary Combination Y and $1\!\!/\!_{\text{B}}$ Bend




Size, in.	E, in.	F, in.	G, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
½ × 1½	41/4	63/4	41/4	1½ × 1½	23/16 × 23/16	11/32
× 1½	41/2	63/4	41/4	2 × 1½	$25/8 \times 23/16$	11/32
! × 1½ × 1½	41/2	63/4	41/4	$2 \times 1\frac{1}{2} \times 1\frac{1}{2}$	$25/8 \times 23/16 \times 23/16$	11/32
× 2	41/2	67/8	41/2	2×2	2 5/8 × 25/8	11/32
× 1½	5	63/4	41/4	3 × 1½	$3\frac{3}{4} \times 2\frac{3}{16}$	11/32
× 2	5	71/4	41/2	3×2	$3\frac{3}{4} \times 2\frac{5}{8}$	11/32
× 3	5	83/8	5	3× 3	$3\frac{3}{4} \times 3\frac{3}{4}$	11/32
× 1½	5%16	67/8	47/32	4× 1½	$4\frac{3}{4} \times 2\frac{3}{16}$	11/32
× 2	51/2	71/4	41/2	4×2	$4\frac{3}{4} \times 2\frac{5}{8}$	11/32
× 3	51/2	81/4	5	4×3	$4\frac{3}{4} \times 3\frac{3}{4}$	11/32
\times 4	51/2	93/8	51/2	4×4	$4\frac{3}{4} \times 4\frac{3}{4}$	11/32

Note 1-1 in. = 25.4 mm.


FIG. 13 Sanitary T Branches

♣ A 861 – 04



		T	ABLE 3	Continued		
Size, in.	E, in.	F, in.	G, in.	ID, in.	OD,	Stop Lug Depth (P),
					in.	in.
1½ × 1½	41/4	63/4	41/4	1½ × 1½	23/16 × 23/16	11/32
$2 \times 1\frac{1}{2}$	41/2	63/4	41/4	$2 \times 1\frac{1}{2}$	$2\% \times 2\%_{16}$	11/32
2×2	41/2	67/8	41/2	2×2	$25/8 \times 25/8$	11/32
$3 \times 1\frac{1}{2}$	5	63/4	41/4	3 ×1½	$3\frac{3}{4} \times 2\frac{3}{16}$	11/32
3×2	5	71/4	41/2	3×2	$3\% \times 2\%$	11/32
3×3	5	83/8	5	3×3	$3\frac{3}{4} \times 3\frac{3}{4}$	11/32
4×2	51/2	71/4	41/2	4×2	$4\frac{3}{8} \times 2\frac{5}{8}$	11/32
4×3	51/2	81/4	5	4×3	$4\frac{3}{4} \times 3\frac{3}{4}$	11/32
4 × 4	51/2	93/8	51/2	4×4	$4\frac{3}{8} \times 4\frac{3}{8}$	11/32


 $\label{eq:Note_1} Note \ 1\text{---}1 \ in. = 25.4 \ mm.$ FIG. 14 Double-Branch Sanitary T



Size, in.	A, in.	B, in.	C, in.	D, in.	J, in.	R, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	23/4	15/8	5	10	4	13/4	11/2	23/16	11/32
2	31/2	1 ¹⁵ / ₁₆	51/2	11	4	2	2	25/8	11/32
3	4	25/16	61/2	13	51/2	21/2	3	33/4	11/32
4	41/2	3	71/2	15	61/2	3	4	43/4	11/32


Note 1—1 in. = 25.4 mm.

FIG. 15 Sanitary Running Traps



Size, in.	A, in.	B, in.	C, in.	D, in.	J, in.	R, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	33/4	15/8	31/2	63/4	4	13/4	11/2	23/16	11/32
2	4	1 15/16	4	71/2	4	2	2	25/8	11/32
3	41/2	25/16	5	9	51/2	21/2	3	33/4	11/32
4	5	3	6	101/2	61/2	3	4	43/4	11/32


Note 1—1 in. = 25.4 mm. FIG. 16 Sanitary P Traps



Size, in.	C, in.	D, in.	E, in.	F, in.	G, in.	H, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
1½	8 ³ / ₄	4	6 ¹⁵ / ₁₆	5 ⁷ / ₁₆	1¾32	12½	1½	2 ³ / ₁₆	11/32
	9 ³ / ₄	4½	7 ³ / ₄	5 ³ / ₄	1¾8	12	2	2 ⁵ / ₈	11/32

 $\label{eq:Note_loss} Note \ 1\text{—}1 \ in. = 25.4 \ mm.$ FIG. 17 Swivel Trap P-Style Short

∰ A 861 – 04




			٦	TABLE	3 Co	ontinued	1		
Size, in.	C ^A , in.	D, in.	E, in.	F, in.	G, in.	H ^A , in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	123/4	4	615/16	57/16	13/32	121/2	11/2	23/16	11/32

^AFor shorter C or H dimension, snap-cut to desired length.


Note 1—1 in. = 25.4 mm.

FIG. 18 Swivel Trap P-Style Long



Size, in.	C, in.	F, in.	G, in.	H, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
1½	6	8	14¾	22¾	1½	2 ³ / ₁₆	1½2
	6%	10½	12	17⅓	2	2 ⁵ / ₈	1⅓32


 $\label{eq:Note_note} Note \ 1\text{---}1 \ in. = 25.4 \ mm.$ FIG. 19 Swivel Type-S Style Long



Size, in.	B, in.	C, in.	D, in.	E, in.	F, in.	H, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	8	4	4	6¾	12¾	1215/16	11/2	23/16	11/32
2	41/2	43/4	41/2	79/16	141/4	141/4	2	25/8	11/32

NOTE—1 in. = 25.4 mm.

FIG. 20 Centrifugal Drum Trap P Swivel Type



Size, in.	C, in.	D, in.	E, in.	F, in.	J, in.	ID, in.	OD, in.	Stop Lug Depth (P), in.
11/2	4	53/32	63/4	123/4	4	11/2	11/8	11/32
11/2	4	1515/32	63/4	123/4	4	11/2	11/8	11/32
2	43/4	511/16	7 %16	141/4	43/4	2	2	11/32

Note 1—1 in. = 25.4 mm.

FIG. 21 Centrifugal Drum Trap S Swivel Type







TABLE 3 Continued							
Size, in.	В,	E,	F,	G,			
	in.	in.	in.	in.			
2	27/16	33/4	67/8	37/16			
3	33/8	411/16	83/8	43/16			
4	37/8	57/16	93/8	411/16			

Note 1—1 in. = 25.4 mm.

FIG. 22 Combination Cleanout and Test Tees



Size, in.	A, in.	B, in.
11/2	3%	27/8
2	4	33/8
3	47/16	43/16
4	415/16	53/16


Note 1-1 in. = 25.4 mm.

FIG. 23 Coupling



Size, in.	F, in.
1/2	2
2	2½ 2½ 2½
3	21/2
4	21/2

Note 1—1 in. = 25.4 mm. FIG. 24 Pipe Plugs



Size, in.	A, in.	D, in.	E, in.	F, in.	
11/2	23/16	21/4	15/16	3%16	
2	221/32	21/4	15/16	39/16	
3	33/4	21/2	13/8	37/8	
4	43/4	23/4	17/16	43/16	

Note 1-1 in. = 25.4 mm. FIG. 25 Cleanout Plugs







		TABLE 3	Continued		
Size, in.	A, in.	B, in.	E, in.	F, in.	
1½ × 1½	323/32	21/4	9/16	45/8	
$1\frac{1}{2} \times 2$	313/16	221/32	9/16	45/8	
$1\frac{1}{2} \times 3$	313/16	313/16	9/16	45/8	
$1\frac{1}{2} \times 4$	313/16	413/16	9/16	47/8	
2×2	45/16	223/32	5/8	51/8	
2×3	45/16	313/16	5/8	43/4	
2×4	45/16	413/16	5/8	5	
3×3	55/16	313/16	11/16	53/8	
4×4	69/32	47/8	11/16	59/16	


Note 1—1 in. = 25.4 mm.

FIG. 26 Adapter/Hub to No-Hub




	Size, in.	B, in.	F, in.
_	2 × 1½	11/2	8
	$3 \times 1\frac{1}{2}$	11/2	8
	3×2	11/2	8
	$4 \times 1\frac{1}{2}$	11/2	8
	4×2	11/2	8
	4 × 3	1½	8

Note 1—1 in. = 25.4 mm. FIG. 27 Reducers-Increasers



Size, in.	A, in.	B, in.	C, in.	D, in.	E, in.	F, in.
11/2	0 to 2	101/4	17/8	35/16	1/4	23/16


Note 1—1 in. = 25.4 mm. **FIG. 28 Sink Outlet**



A, in. ^A	B, in. ^A	C, in.
4	61/8	1
6	81/8	1
8	101//8	1

^ADimension A and B will vary depending upon the sink strainer in which overflow is placed, depth of counterbore, and so forth, Dimension B is given only as a guide.

Note 1—1 in. = 25.4 mm. FIG. 29 Sink Overflows




NPSM Threads (National Pipe Straight Mechanical)

Туре	Size, in.
AD-7	11/2 Outlet to 11/2 MJ
AD-8	11/2 Outlet to 2 MJ
AD-10	2 Outlet to 2 MJ

Note 1—1 in. = 25.4 mm.

FIG. 30 Threaded Adapters





 $\label{eq:note_norm} \mbox{Note } 1 \mbox{$--$1$ in.} = 25.4 \mbox{ mm}.$ FIG. 31 Trap Cleanout Details




	TABLE 3 Continued	
Size, in.	A, in.	J, in.
2	5¾	6
3	7	71/2
4	8	9

Note 1—Flange dimensions are 150 lb ANSI standard.

Note 2—1 in. = 25.4 mm.

FIG. 32 Adapter—No-Hub and Split Flange






		TABLE 3	Continued	
Туре	Size, in.	B, in.	C, in.	D, in.
AD-11 AD-12	1½ 2	2½ 2 ²³ / ₃₂	1½ 1½	1 ²⁵ / ₃₂ 2 ⁹ / ₃₂
AD-12		Z ² 9/32	1 72	Z%32

Note 1—1 in. = 25.4 mm. FIG. 33 MJ to Lead Adapter



Note 1—1 in. = 25.4 mm. FIG. 34 Floor Drains


♣ A 861 – 04



		TABL	E 3 Con	tinued			
Size, in.	A, in.	B, in.	C, in.	D, in.	E, in.	F, in.	
2	49/16	43/16	35/16	21/32	211/16	25/8	
3	55/16	53/16	45/16	31/8	325/32	25/8	
4	63/8	63/16	55/16	41/8	425/32	25/8	
6	817/32	811/32	7 5/ ₁₆	5 ¹⁵ / ₁₆	611/16	3	
8	111/4	103/4	95/8	81/4	9	3	
10	141/4	13¾	121/4	10	111/4	37/8	
12	16¾	16	141/2	12	131/4	4	
15	201/4	19¾	173/4	15	16¾	41/8	


Size, in.	t, in.	Weight, lb	Working Length, ft	Overall Length
2	5/16	0.31	7	7 ft 25/8 in.
3	5/16	0.31	7	7 ft 25/8 in.
4	5/16	0.31	7	7 ft 25/8 in.
6	13/32	0.40	7	7 ft 3 in.
8	13/32	0.40	7	7 ft 3 in.
10	5/8	0.62	7	7 ft 31/8 in.
12	5/8	0.62	5	5 ft 4 in.
15	7/8	0.75	5	5 ft 41/8 in.

Note 1—1 in. = 25.4 mm. FIG. 35 Hub and Plain End Pipe



Size, in.	Weight, lb	A, in.	B, in.	C, in.
2 × 1½	11	81/2	17/8	65/8
2×2	12	9	2	7
3×2	17	9	21/2	613/16
3×3	19	10	21/2	71/2
4×2	20	9	3	7
4×3	221/2	10	3	71/4
4×4	26	11	3	8

Note 1—1 in. = 25.4 mm. FIG. 36 Straight Tees



Size, in.	Weight, Ib	A, in.	B, in.	C, in.
2 × 1½	11	81/2	31/2	63/4
2×2	12	9	31/2	7
$3 \times 1\frac{1}{2}$	16	81/2	4	63/4
3×2	18	9	4	7
3×3	20	10	4	71/2
$4 \times 1\frac{1}{2}$	18	81/2	41/2	63/4
4×2	19	9	41/2	7
4×3	26	10	41/2	71/2
4×4	28	11	41/2	8
6×2	31	9	51/2	7
6×3	33	10	51/2	71/2
6×4	35	11	51/2	8
6×6	50	13	51/2	9
8×4	62	105/8	61/4	8
8×6	65	141/2	65/8	101/2
8×8	113	19	65/8	131/2
10 × 6	130	141/4	7 5/8	101/2
10 × 10	180	21	73/4	141/2
12 × 8	187	19	83/4	131/2

Note 1-1 in. = 25.4 mm.

FIG. 37 Sanitary T Branches

♣ A 861 – 04





TABLE 3 Continued						
Size, in.	Weight, lb	A, in.	B, in.	C, in.		
2 × 1½	11	85%	43/8	43/8		
2×2	12	9	41/4	43/4		
$3 \times 1\frac{1}{2}$	16	85/8	51/16	37/8		
3×2	17	9	5	43/16		
3×3	21	101/2	51/2	5		
$4 \times 1\frac{1}{2}$	17	91/8	5 ¹³ / ₁₆	37/8		
4×2	21	9	53/4	311/16		
4×3	26	101/2	61/4	41/2		
4×4	30	12	63/4	51/4		
6×2	28	9	71/8	211/16		
6×3	35	101/2	7 5/8	31/2		
6×4	45	121/4	81/4	41/4		
6×6	60	143/4	91/8	53/4		
8×2	60	167/ ₈	9	41/2		
8×3	63	121/8	9	33/4		
8×4	65	131/2	10	41/2		
8×6	79	161/2	11	61/16		
8×8	117	191/2	121/4	71/4		
10×4	160	131/2	111/2	31/2		
10×6	165	16 ⁵ /8	131/2	37/8		
10 × 8	170	19¾	143/8	43/8		
10×10	180	221/2	15	7 5/8		
12×4	173	181/4	153/16	41/2		
12×6	196	181/4	161/2	41/2		
12 × 8	200	233/8	15½	5		
12 × 10	275	27	191/2	6		
12 × 12	288	251/2	18¾	71/4		
15 × 15	455	321/8	223/4	81//8		


Note 1—1 in. = 25.4 mm. FIG. 38 Sanitary Y Branches



Size, in.	Weight, Ib	A, in.	B & B, in.	C, in
2 × 1½	14	81/2	7	634
2 × 2	16	9	7	7
3 × 1½	15	81/2	8	63/4
3 × 2	17	9	8	7
3×3	22	10	8	71/2
4 × 1½	18	81/2	9	6¾
4 × 2	21	9	9	7
4×3	24	10	9	71/2
4×4	37	11	9	8
6 × 3	50	10	11	71/2
6 × 4	46	11	11	8
6×6	58	13	11	9
8×6	80	141/2	131/4	101/2
8×8	113	19	65/8	131/2

NOTE—1 in. = 25.4 mm.

FIG. 39 Double-Branch Sanitary Tee




Size, in.	Weight, lb	A, in.	B, in.	C, in.	
2 × 1½	14	85/8	43/8	43/8	
2×2	15	9	41/4	43/4	
$3 \times 1\frac{1}{2}$	19	85/8	51/16	37/8	
3×2	20	9	5	43/16	
3×3	28	101/2	51/2	5	
$4 \times 1\frac{1}{2}$	21	91/8	5 ¹³ / ₁₆	37/8	
4×2	23	9	53/4	311/16	
4×3	26	101/2	61/4	41/2	
4×4	33	12	63/4	51/4	
6 × 2	31	9	71/8	211/16	
6 × 3	46	101/2	75/8	31/2	
6 × 4	52	12	81/8	41/4	
6 × 6	65	143/4	91/8	53/4	
8×4	71	131/2	10	101/2	
8×6	86	161/2	11	61/16	

Note 1—1 in. = 25.4 mm.


FIG. 40 Double-Branch Sanitary Y






	T.	ABLE 3	Continued		
Size, in.	Weight, lb	A, in.	B and B, in.	C, in.	E, in.
2 × 1½	15	85/8	91/4	43/8	73/8
2×2	17	9	101/2	43/4	81/4
3 × 1½	17	85/8	101/4	37/8	73/8
3×2	22	9	111/2	43/16	83/16
3×3	27	101/2	13	5	9%16
$4 \times 11/_2$	24	91/8	113/4	37/8	81/8
4×2	24	9	121/2	311/16	83/16
4×3	28	101/2	14	41/2	9%16
4×4	40	12	151/2	51/4	1013/16
6×3	45	101/2	16	31/2	9%16
6×4	57	12	17 ½	41/4	1013/16
6 × 6	83	15	201/2	53/4	137/16

 $No{\rm TE}~1{\longrightarrow}1~in.=25.4~mm.$ FIG. 41 Double-Branch Sanitary Combination Y and $1\!\!/\!\!_{8}$ Bend (T-Y)




Size, in.	Weight, lb	B, in.	C, in.
2	11	51/4	8
3	20	6	9
4	25	61/2	10

Note 1-1 in. = 25.4 mm. FIG. 42 Short-Sweep Quarter Bends



Size, in.	Weight, Ib	B, in.	C, in.	
2	14	81/2	12	
3	24	9	121/2	
4	29	91/2	13	
6	47	101/2	14	
8	98	11½	15	

Note 1—1 in. = 25.4 mm. FIG. 43 Long-Sweep Quarter Bends



Size, in.	Weight, lb	A, in.	B, in.	C, in.	E, in.
2 × 1½	11	85/8	45/8	43/8	73/8
2×2	13	9	51/4	43/4	81/4
$3 \times 1\frac{1}{2}$	14	85/8	51/8	37/8	73/8
3×2	18	9	53/4	43/16	83/16
3×3	24	101/2	61/2	5	99/16
$4 \times 1\frac{1}{2}$	17	91/8	57/8	37/8	81/8
4×2	21	9	61/4	311/16	83/16
4×3	23	101/2	7	41/2	9%16
4×4	31	12	73/4	51/4	103/16
6×2	33	9	71/4	211/16	83/16
6×3	37	101/2	8	31/2	99/16
6×4	47	12	83/4	41/4	10 ¹³ / ₁₆
6×6	63	15	101/4	53/4	137/16
10×6	185	163/4	121/2	47/16	43/8
10 × 8	192	213/8	151/8	61/2	181/2

 $No{\rm TE}~1{\longrightarrow}1~in.=25.4~mm.$ FIG. 44 Sanitary Combination Y and $1\!\!/\!\!_{\text{B}}$ Bend (T-Y)





	TABLE 3	Continued	
Size,	Weight,	B, in.	C, in.
III.	ID	III.	111.
2	9	31/2	7
3	16	4	71/2
4	20	41/2	8
6	36	51/2	9
8	54	61/8	10
10	116	85/8	12
12	195	10%	14

Note 1—1 in. = 25.4 mm. FIG. 45 Quarter Bends



Size, in.	Weight, lb	B, in.	C, in.	
2	7	13/4	51/4	
3	13	1 ¹⁵ / ₁₆	57/16	
4	16	23/16	5 ¹¹ / ₁₆	
6	25	29/16	61/16	
8	46	311/16	813/16	
10	95	41/4	91/4	
12	132	5	95/8	

Note 1—1 in. = 25.4 mm. FIG. 47 Eighth Bends



_					
	Size, in.	Weight,	B, in.	C, in.	
	2	8	21/4	53/4	
	3	11	21/2	6	
	4	15	23/16	6 5/16	
	6	27	33/8	67/8	
	8	71	41/8	9	

Note 1—1 in. = 25.4 mm. FIG. 46 Sixth Bends



Size, in.	Weight, lb	B, in.	C, in.	
2	6	11/8	45/8	
3	8	13/16	411/16	
4	11	15/16	413/16	
6	21	11/2	5	
8	44	21/16	71/8	
10	80	2	67//8	

Note 1—1 in. = 25.4 mm. FIG. 48 Sixteenth Bends





	TABLE 3 Continued	
Size,	Weight,	A,
in.	lb	in.
2 × 3	9	9
2×4	13	9
2×6	17	9
3×4	17	9
3×6	16	9
4×6	17	9
4 × 8	33	115⁄8
6 × 8	50	117/8
8 × 10	85	16

Note 1—1 in. = 25.4 mm. FIG. 49 Sanitary Increasers



Size, in.	Weight, lb
2	21/2
3	3
4	5
6	10
8	18

Note 1—1 in. = 25.4 mm. FIG. 50 Hub Strainers






Hub

Size, in.	Weight, lb	A, in.
3 × 1½	6	5
3×2	7	5
$4 \times 1\frac{1}{2}$	7	5
4×2	9	5
4 × 3	11	5
6 × 2	12	5
6 × 3	13	5
6×4	14	5
8 × 4	22	6
8 × 6	25	6
10 × 6	39	6
10 × 8	51	6
12 × 6	55	61/2
12 × 8	65	6
12 × 10	83	6
15 × 6	79	6
15 × 12	109	6

Note 1—1 in. = 25.4 mm. FIG. 51 Sanitary Reducers



Size, in.	Weight, lb	A, in.
2	61/2	1
3	9	1
4	12	1
6	18	1
8	40	2
10	82	2

Note 1—1 in. = 25.4 mm. FIG. 52 Double Hubs






TABLE 3	Continued	
Size, in.	Weight, lb	
2 3 4 6 8	2 3 5 10 17 56	


Note 1—1 in. = 25.4 mm.

FIG. 53 Pipe Plugs



Size in.	, Weight,	
2	3½ 6½	
3	61/2	
4	11	
6	14	
8	26	
10	39	


Note 1—1 in. = 25.4 mm. FIG. 54 Cleanout Plugs



Size, in.	Weight, lb	A, in.	J, in.
2	5	53/4	6
3	11	7	7 ½
4	12	8	9
6	22	91/2	11
8	44	10¾	131/2

Note 1—1 in. = 25.4 mm.


FIG. 55 Adapter—Plain-End and Split Flange



Size, in.	Weight, lb	A, in.	J, in.
2	5	21/2	6
3	7	21/2	71/2
4	12	23/4	9
6	16	3	11
8	36	31/2	131/2

Note 1—1 in. = 25.4 mm.

FIG. 56 Adapter—Hub and Split Flange



Size, in.	Weight, lb	A, in.	B, in.	C, i n.	D, in.	E, in.	F, in.
2	12	21/2	9	313/16	35/8	31/16	27/8
3	22	27/8	10	5	45/8	41/4	313/16
4	29	39/16	11	57/16	55/8	41/2	413/16

Note 1—1 in. = 25.4 mm.

FIG. 57 Combination Cleanout and Test Tees








TABLE 3 Continued									
Plate No.	Size, in.	Weight, lb	A, in.	B, in.					
5045	2	11	73/4	61/2					
5070	3	17	83/8	7 3/8					
5095	4	21	91/8	7 7/8					
5144	6	37	91/8	7 7/8					

Note 1-1 in. = 25.4 mm. FIG. 58 Insertable Joints



Size, in.	
3	
4	
6	
8	

Note 1—1 in. = 25.4 mm. FIG. 59 Backwater Valves



Size, in.	Without Vent Weight, Ib	Hub Vent Weight, Ib	A, in.	B, in.	C, in.	D, in.	E, in.	G, in.	H, in.	Vent, in.
2	12	16	11	3	61/4	41/2	21/4	313/16	15/8	2
3	25	32	121/2	41/4	61/4	51/2	3	41/2	25/16	3
4	37	45	14	51/2	7	61/2	31/4	53/16	3	4
6	68	80	17	81/2	8	81/2	4	61/2	315/16	4

Note 1—Depth of seal on all traps shall be $2 \ensuremath{^{1\!\!/\!\!2}}$ in.

Note 2—1 in. = 25.4 mm.

FIG. 60 Sanitary P Traps







					TABLE 3	Continued					
Size, in.	Without Vent, Weight, Ib	Hub Vent, Weight, Ib	A, in.	B, in.	C, in.	D, in.	E, in.	F, in.	G, in.	H, in.	Vent, in.
2	16	18	91/4	3	8	41/2	33/4	43/4	313/16	15/8	2
3	24	29	101/2	41/4	10	51/2	41/4	61/4	41/2	25/16	3
4	33	39	111/4	51/2	12	61/2	41/4	7	53/16	3	4
6	82	89	14	81/2	16	81/2	5	9	61/2	315/16	4

Note 1—Depth of seal on all traps shall be $2\frac{1}{2}$ in. Note 2—1 in. = 25.4 mm.

FIG. 61 Sanitary S Traps



Size, in.	Without Vent, Weight, lb	Single Hub Vent, Weight, Ib	Double Hub Vent, Weight, Ib	A, in.	B, in.	D, in.	E, in.	F, in.	G, in.	H, in.	Vent, in.
2	14	17	22	131/2	21/2	41/2	21/2	51/4	85/16	15/8	2
3	29	36	42	151/2	3	51/2	31/4	61/4	10	2 5/16	3
4	41	49	57	171/2	31/2	61/2	31/2	71/4	11 ¹¹ / ₁₆	3	4
6	78	87	168	211/2	41/2	81/2	41/4	81/4	15	315/16	4
8	162	165	208	267/8	51/2	11	37/8	12	187/16	51/4	6
10	330	334	346	311//8	71/8	13	51/8	16	221/4	611/16	6

Note 1—Single hub vent is located on the inlet side. Depth of seal on 8 and 10-in. traps is 3 in. All others 2½ in.

Note 2—1 in. = 25.4 mm.

FIG. 62 Sanitary Running Traps



- l (without flashing ring)
- 2 (with flashing ring)




	TABLE 3 Continued	
Plate	Outlet	Weight, lb
No.	Size, in.	
1	2, 3, 4 and 6	45
2	2, 3, 4 and 6	45
3	2, 3, 4 and 6	53
4	2, 3, 4 and 6	53
5	2, 3, 4 and 6	41
6	2, 3, 4 and 6	42
7	2, 3, 4 and 6	48
8	2, 3, 4 and 6	49

Note 1—1 in. = 25.4 mm.

FIG. 63 Outside Caulk

3 (without flashing ring)

4 (with flashing ring)





Plate No.	Size, in.	A, in.	B, in.	C, in.
5, 6, 7, 8	2	27/8	31/2	5/16
	3	37/8	41/2	5/16
	4	47/8	51/2	3/8
	6	7	73/4	3/8

Note 1—1 in. = 25.4 mm.

FIG. 64 Outside Caulk with Basin




- 5 (without flashing ring)
- 6 (with flashing ring)
- 7 *(with sediment basin and without flashing ring)



Note 1—1 in. = 25.4 mm. FIG. 65 Inside Caulk

Plates 1, 2

Plates 3,4
(With Sediment Basin)



		TA	BLE 3	Continue	ed		
	Plate No.	Outlet Size, in.					lb
	1 2 3 4		3 4 2 2	1		70 73 37 45	
Plate No.	Size, in.	A, in.	B, in.	C, in.	D, in.	E, in.	F, in.
1 2	3 4	8 8	9 9	57/8 63/8	1½ 1½	14 14	14½ 14½

Note 1—1 in. = 25.4 mm. FIG. 66 Floor Drains

With Flashing Ring





FIG. 67 Method of Installation



 $\label{eq:Note_note} No{\tt TE} \ 1\text{---}1 \ in. = 25.4 \ mm.$ FIG. 68 Floor Drain Funnel Attachment




TABLE 3 Continued									
	Plate No.	A, in. ^A	B, in. ^A	C, in.					
	1	2	41/8	1					
	2	4	61/8	1					
	3	6	81/8	1					
	4	8	101/8	1					
	5	0	21/8	1					

^ADimensions A and B will vary depending upon the sink strainer in which overflow is placed, depth of counterbars, and so forth. Dimension B is given only as a guide.

Note 1—1 in. = 25.4 mm.

FIG. 69 No. 1, 2, 3, 4, and 5 Overflows




Plate No.	Size, in.	A, in.	B, in.	C, in.	D, in.	E, in.
1	1½ or 2	3/4 to 11/4	10	31/2	43/8	1/8
2	11/2 or 2	1 to 2	10	21/2	37/8	7/16
3	11/2 or 2	1 to 2	10	21/2	3	1/4
4	11/2	0 to 2	101/4		35/16	1/4

Note 1—Furnished with flat loose strainer plates.

Nоте 2—1 in. = 25.4 mm.

FIG. 70 Sink Outlet









TABLE 3 Continued									
Size, in.	Diameter of Drain, in.	A, in.							
Under 6 6 and over	1½ 2¼	2 ³ / ₁₆ 2 ⁹ / ₁₆							

Note 1—Traps can be supplied without cleanouts, as shown in the figure.

Note 2—1 in. = 25.4 mm.

FIG. 71 Detailed Cross Section of Cleanout



Note 1—It is recommended that the casting be mold-cooled to below $1000^{\circ}F$ ($540^{\circ}C$) before shakeout, and that the test bars be stress-relieved before transverse testing.

FIG. 72 Transverse Bend Test Bar Dimensions






TABLE 3 Continued														
Metric Equivalents														
in.	1/4	1/2	3/4	13/16	1	11/8	17/32	11/4	11/2	15/8	21/2	91/2	133/16	151/16
mm	6.4	12.7	19.0	20.6	25.4	28.6	31.0	31.8	38.1	41.3	63.5	241.3	335.0	382.6

FIG. 73 Suggested Pattern for Transverse Bend Test Bar, Cast Horizontally, 1.20 in. (30.5 mm) in Diameter

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).