



Standard Specification for Surge Suppressors for Shipboard Use¹

This standard is issued under the fixed designation F 1507; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last approval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This standard establishes performance requirements of surge suppressors for use on shipboard ac power circuits.

1.2 Surge suppressor shall be a protective device for limiting voltage transients on equipment by discharging, dissipating internally, bypassing surge current, or a combination thereof and which prevents continued flow of follow current to ground and is capable of repeating these functions.

1.3 Surge suppressors covered by this specification may consist of a single circuit element or may be a hybrid device using several suppression devices.

2. Referenced Documents

2.1 The following documents of the issue in effect on the date of material purchase form a part of this specification to the extent referenced herein:

2.2 *American National Standards:*²

ANSI/IEEE Std 4 IEEE Standard Techniques for High Voltage Testing

ANSI/IEEE C62.41 Recommended Practice on Surge Voltage in Low-Voltage AC Power Circuits

ANSI/IEEE C62.45 Guide on Surge Testing for Equipment Connected to Low-Voltage AC Power Circuits

ANSI/IEEE C84.1 Electrical Power Systems and Equipment—Voltage Ratings

2.3 *Military Standard:*³

MIL-STD-1399 Section 300; Military Standard Interface Standard for Shipboard Systems, Section 300, Electric Power, Alternating Current

2.4 *Underwriters Laboratories Standard:*⁴

UL 1449 Transient Voltage Surge Suppressors, 2nd Edition

¹ This specification is under the jurisdiction of ASTM Committee F25 on Ships and Marine Technology and is the direct responsibility of Subcommittee F25.10 on Electrical.

Current edition approved Nov. 11, 1999. Published March 2000. Originally published as F 1507 – 94. Last previous edition F 1507 – 94.

² Available from American National Standards Institute, 11 W. 42nd St., 13th Floor, New York, NY 10036.

³ Available from Standardization Documents Order Desk, Bldg. 4 Section D, 700 Robbins Ave., Philadelphia, PA 19111-5094, Attn: NPODS.

⁴ Available from Underwriters Laboratories, Inc., 333 Pfingsten Rd., Northbrook, IL 60062.

3. Terminology

3.1 Definitions:

NOTE 1—These definitions other than specific to the standard are taken from UL 1449, ANSI/IEEE C62.41, and MIL-STD 1399 to provide for harmonization of terms.

3.2 *power interface*—The electrical points where the surge suppression device is electrically connected to the ac power system.

3.3 *combination wave*—A surge delivered by an instrument that has the inherent capability of applying a 1.2/50- μ s voltage wave across an open circuit and delivering an 8/20- μ s current wave into a short circuit. The exact wave that is delivered is determined by the instantaneous impedance to which the combination wave is applied. (Also called combination voltage/current surge or combination V/I surge.)

3.4 *crest (peak) value (of a wave, surge or impulse)*—The maximum value that a wave, surge, or impulse attains.

3.5 *electric power source*—The electric power that is supplied for testing.

3.6 *electric power system ground*—Ground is a plane or surface used by the electric power system as a common reference to establish zero potential. Usually, this surface is the metallic hull of the ship. On a nonmetallic hull ship, a special ground system is installed for this purpose.

3.7 *follow (power) current*—The current from the connected power source that flows through a surge protective device following the passage of discharge current.

3.8 *frequency tolerance*—Frequency tolerance is the maximum permitted departure from nominal frequency during normal operation, excluding transient and cyclic frequency variations. This includes variations such as those caused by load changes, switchboard frequency meter error, and drift. Unless specified otherwise, frequency tolerance shall be considered to be $\pm 10\%$ of nominal frequency.

3.9 *inrush current*—The inrush current is a sudden change in line current that occurs during startup or as a result of a change to the operating mode. Inrush current is dependent on the type of load connected to the surge suppressor, and typically will rise to a maximum value in a few milliseconds and decay to rated value in several milliseconds to several seconds.

3.10 *leakage current*—Line current drawn, either line-to-line or line-to-ground, by the suppressor when operated at the maximum continuous operating voltage.

3.11 *maximum continuous operating voltage*—Maximum sinusoidal rms voltage which may be continuously applied without degradation or deleterious effects.

3.12 *measured limiting voltage*—The crest (peak) value of the voltage measured at the leads, terminals, receptacle contacts and the like, intended for connection to the load(s) to be protected, and resulting from application of a specified surge.

3.13 *nominal frequency*—the nominal frequency is the designated frequency in Hz.

3.14 *nominal system voltage*—A nominal value assigned to designate a system of a given voltage class in accordance with ANSI/IEEE C84.1. For the purpose of this standard, nominal system voltages are 120, 208, 240, and 480 vac. All voltages in this standard are root-mean-square (rms) unless stated otherwise. All tolerances are expressed in percent of the nominal system voltage.

3.15 *one-port transient voltage surge suppressor*—A TVSS having one set of electrical connections (terminals, leads and the like) intended only for shunt-connection to the ac power circuit, such that load current in the ac power circuit bypasses the TVSS.

3.16 *peak overshoot voltage*—Maximum voltage above the voltage protection level (peak voltage minus suppression voltage rating) across the suppressor output terminals during initial response to a voltage spike.

3.17 *rated rms voltage (varistor)*—Maximum continuous sinusoidal rms voltage which may be applied to a varistor.

3.18 *response time (varistor)*—The time between the point at which the wave exceeds the voltage protection level (suppression voltage rating) and the peak of the voltage overshoot. For the purpose of this definition, voltage protection level is defined with an 8/20- μ s current waveform of the peak current amplitude as the waveform used for this response time.

3.19 *secondary surge arrestor*—A surge protector device acceptable ahead of the service entrance equipment on circuits not exceeding 1000-V rms (location category C as described in ANSI/IEEE C62.41).

3.20 *surge*—A transient overvoltage superimposed on the ac power circuit. A voltage surge is generally one in which the superposition of the surge and normal power frequency voltage involves peak voltage levels of twice or more the normal voltage of the ac power system and generally lasting not more than one-half period of the nominal system voltage waveform.

3.21 *surge protective device (SPD)*—A protective device composed of any combination of linear or non-linear circuit elements and intended for limiting surge voltages on equipment by diverting or limiting surge current; it prevents continued flow of follow (power) current and is capable of repeating these functions as specified.

3.22 *temporary overvoltage (TOV)*—A voltage swell from a sudden change in voltage which goes outside the voltage tolerance limits but does not exceed 120 % of nominal system voltage and returns to and remains within these limits within 2 s after the initiation of the disturbance.

3.23 *transient voltage surge suppressor (TVSS)*—A surge protective device intended for connection electrically on the load side of the main overcurrent protection in circuits not exceeding 600 V. (Location Categories A and B as described in ANSI/IEEE C62.41.)

3.24 *two-port transient voltage surge suppressor*—A TVSS having one set of electrical connections (terminals, leads and the like) intended for connection to the ac power circuit and one or more separate sets of electrical connections (terminals, leads, outlet receptacles, and so forth) intended for connecting the load(s) to be protected. This device is series-connected such that load current will flow through the transient voltage surge suppressor.

3.25 *voltage drop*—Voltage differential measured from input terminals to output terminals under conditions of rated load current for two-port surge suppressors.

3.26 *voltage protection level*—A suppression rating (or ratings) in volts or kilovolts, selected by the manufacturer that is based on the measured limiting voltage determined during surge testing. Also referred to as the suppression voltage rating.

3.27 *voltage spike*—A voltage spike is a voltage change of very short duration (100 μ s to 1/2 cycle). The standard 1.2/50- μ s lightning impulse, as defined by ANSI/IEEE Std 4, is the characteristic voltage spike used for test purposes.

3.28 *voltage tolerance*—Voltage tolerance is the maximum permitted departure from nominal system voltage during normal operation, excluding transient voltage variations. Voltage tolerance includes variations such as those caused by load changes, switchboard meter error, and drift. Unless otherwise specified, voltage tolerance shall be considered to be ± 10 % of nominal system voltage.

4. Classification

4.1 Surge suppressors covered in this specification shall be classified by class and type.

4.2 The two classes of surge suppressors covered in this specification are based on and reflect ANSI/IEEE C62.41 locations.

4.2.1 *Class A*—Surge suppressor associated with long circuit branch that being greater than 30-ft cable distance from the distribution panel and usually installed as a series-connected TVSS at the distribution system receptacle (wall outlet).

4.2.2 *Class B*—Surge suppressor for short branch circuit, either installed at loads within 30-ft cable distance from the circuit breaker distribution panel or within the distribution panel.

4.3 Type designations for surge suppressors covered in this specification are as follows:

4.3.1 *Type I; Permanent Connected Type*—A suppressor designed for hard-wired or panel-mount applications. This type surge suppressor is the only one-port-type TVSS.

4.3.2 *Type II; Plug-In Type*—A suppressor provided with blades for direct connection at a receptacle and with integral output receptacle(s). By nature of its design, a plug-in suppressor is inserted into the circuit as a series connection.

4.3.3 *Type III; Cord-Connected Type*—A suppressor that is connected to a receptacle through a flexible cord that is permanently attached to the suppressor device. The cord shall

be in accordance with requirements of UL 1449. Cord-connected devices shall not have means for permanent mounting.

4.3.4 *Type IV; Power Director (Power Center) Type*—A suppressor unit with two-pole main circuit breaker, a master switch for controlling all receptacle outlets, and individual switches for controlling all outlets.

5. Ordering Information

5.1 Orders for suppressors under this specification shall include the following:

- 5.1.1 This specification number;
- 5.1.2 Nominal system voltage—120, 208, 240, and 480 V;
- 5.1.3 Frequency—50, 60, and 400 Hz;
- 5.1.4 Service—single-phase, three-phase delta, three-phase wye;
- 5.1.5 Load current;
- 5.1.6 Surge suppressor—class and type;
- 5.1.7 Protection modes;
- 5.1.8 Voltage protection level (suppression rating), if known;
- 5.1.9 Quantity;
- 5.1.10 Testing requirements—include only if tests other than the production tests required by this specification are to be performed;
- 5.1.11 Certification requirements; and
- 5.1.12 Packaging and shipping requirements.

6. Materials and Manufacture

6.1 *Materials*—All materials used in the construction of these surge suppressors shall be of a quality suitable for the purpose intended and shall conform to the requirements of this specification.

6.1.1 All metallic enclosures shall be either painted or coated with corrosion resistant material.

6.2 *Manufacture*—Plastic, when used, shall be a suitable thermoplastic or thermosetting material so molded as to produce a dense solid structure, uniform in texture, finish, and mechanical properties.

7. Requirements

7.1 Performance Requirements:

Maximum continuous operating voltage	110 % of nominal voltage
Temporary overvoltage withstand	120 % of nominal voltage for 2 s
Voltage drop ^A	Less than 0.25 % of nominal voltage at rated current
System frequency tolerance	± 10 % of nominal frequency
Voltage protection level ^B	
120-V nominal suppressor	± 350 V
208-V, 240-V nominal suppressor	± 700 V
480-V nominal suppressor	± 1200 V
Maximum peak overshoot voltage	Less than 250-V overvoltage protection level for voltage spike with 5 kV/μs or lower rate of rise
Response time	Less than 50 ns
Maximum leakage current	Less than 30-mA line-line or line-ground

Inrush current	10 times rated current for 10 cycles
Peak surge current	3000 A
Operating temperature	–10 to 60°C
Storage temperature	–40 to 85°C
Minimum insulation resistance to case	10 MΩ at 500 VDC
Humidity resistance	0 to 100 %
Minimum life	2000 operations

^A For two-port (plug-in and series-connected) suppressors only.

^B Measured line-to-line and line-to-neutral with an 8/20-μs, 3000-A peak wave-form per ANSI/IEEE C62.41 applied.

7.2 Operating Requirements:

7.2.1 Protection modes for all two-port hybrid surge protective devices shall provide protection for common mode (line-to-ground and neutral-to-ground) and normal mode (line-to-line) transients.

7.2.2 Fails to an open (versus short) circuit unless otherwise specified and provides indication (visual) of failure.

7.2.3 Capable of installation into a dedicated container for mounting or as an assembly or component of a switchboard or power supply.

7.2.4 Maximum voltage drop for two-port devices at full current/voltage shall not exceed 0.25 % of nominal system voltage.

7.3 Grounding Requirements:

7.3.1 The surge suppressor shall be provided with a means for grounding all exposed dead-metal parts that might become energized. Grounding shall be accomplished in accordance with the requirements of UL 1449.

7.3.2 Type I (permanently connected) suppressors requiring grounding shall have a field-wiring terminal or an insulated ground lead that is intended solely for connection of a grounding conductor.

7.3.3 The flexible cord of Types III and IV suppressors which requires grounding shall have a grounding conductor connected to the suppressor enclosure. Type II, direct plug-in, suppressors requiring grounding shall be provided with a grounding pin as one of the attachment plug contacts.

7.3.4 Any leads emanating from a suppressor are to be of color coded insulated wire. The color green shall be used for the grounding conductor and shall not be used for any other purpose.

7.4 Supplementary Protection:

7.4.1 Surge protective devices that are series-connected (Types II, III, and IV) shall have supplementary overcurrent protection and overtemperature protection.

7.4.2 Supplementary overcurrent protection using fuses shall be readily replaceable while circuit breaker protected devices shall be resettable.

7.4.3 Supplementary overcurrent protection shall interrupt all phases of the source circuit plus the circuit neutral where applicable to assure suppressor isolation of the load.

7.4.4 Overtemperature protection shall sense suppressor enclosure or suppression device overtemperature condition and initiate opening of the voltage supply.

7.4.5 Suppressor supplementary protection shall provide a visual or audible indication or both of the opening of the protective device.

8. Enclosures

8.1 Unless specified differently by the purchaser, the suppressor shall be packaged in a safety grounded enclosure with foundation attachments that meets the requirements of UL 1449.

8.1.1 The enclosure shall be capable of confining any material that may be expelled during a catastrophic failure of any suppression device.

9. Receptacles

9.1 Receptacles provided as part of a suppressor shall have a current rating not more than the current rating of the suppressor and a voltage rating consistent with rating of the suppressor.

9.2 All receptacles shall be of the grounding type.

10. Design Tests

10.1 *Insulation Withstand Test*—The assembled insulating members of the surge suppressor shall withstand impulse and power-frequency voltages applied between each pair of line terminals and between each line terminal and the grounded case. Internal parts designed to conduct to discharge impulses shall be removed or rendered inoperative to permit these tests.

10.1.1 *Impulse Insulation Withstand*—A 1.2/50- μ s impulse voltage wave, as defined by ANSI/IEEE Std 4, shall be applied between each set of line terminals and between each line terminal and ground. The magnitude of the impulse voltage shall be at least 1.2 times the sum of the voltage protection level (suppression rating) and the maximum peak overshoot voltage, but need not exceed 6 Kv.

10.1.2 *Power Frequency Insulation Withstand*—An ac potential of the nominal system frequency shall be applied for a period of 1 min between each set of line terminals and between each line terminal and ground. The magnitude of the test voltage shall be 1000 V plus twice nominal system voltage. The same test voltage magnitude shall be applied for line-to-line and line-to-ground tests.

10.2 *Power Frequency Withstand Test*—Power frequency withstand tests shall be performed to demonstrate the ability of the surge suppressor to withstand sustained periods of operation at the maximum continuous operating voltage and periods of transient power frequency overvoltage without degradation. The power supply voltage, measured at the input terminals of the suppressor, shall be maintained as close as practicable to, but not less than, the specified test voltage. Three suppressors shall be connected across a power supply within the tolerances of the nominal frequency. The power supply shall have a short circuit capacity, measured at the suppressor input terminals, of at least 500 amps. For multi-phase suppressors, tests shall be performed for the assembled suppressor and power frequency voltage shall be applied to all phases.

10.2.1 *Maximum Continuous Operating Voltage*—The three test samples shall be placed in a controlled-temperature chamber with an ambient temperature of $85^{\circ}\text{C} \pm 5^{\circ}\text{C}$ and the rated maximum continuous operating voltage shall be applied for a period of 1000 h. The suppressor leakage currents shall be measured at the beginning of the test (after the suppressor temperature has stabilized), and again after 1000 h. The

leakage currents at the conclusion of the test shall be less than 30 mA and shall be less than 110 % of the initial leakage current for each sample.

10.2.2 *Maximum Line-to-Ground Voltage*—Rated maximum continuous operating voltage shall be applied to the three test suppressors between each line terminal and ground for a period of 1 h. A single-phase voltage source may be applied between all line terminals (in parallel) and ground for this test. Leakage current to ground shall not increase by more than 10 % at the conclusion of this test.

10.2.3 *Temporary Overvoltage*—The three test samples shall be exposed to ten cycles of temporary overvoltage. Each overvoltage cycle shall consist of 120 % of rated nominal voltage for a period of 2 s followed by the maximum continuous operating voltage for a period of 1 min. The leakage currents shall not exceed 30 Ma and the leakage current immediately following the 1-min period of the last cycle shall not exceed 110 % of the value obtained at the conclusion of the maximum continuous operating voltage test.

10.3 *Impulse Voltage-Time Tests*—The impulse voltage-time tests demonstrate the suppressor's ability to limit overvoltage in response to varying voltage spike rates of rise. Voltage impulses with fast (5-kV/ μ s) and slow (150-V/ μ s) rates of rise and of both polarities shall be applied between each set of input line terminals and between each line terminal and ground. Normal operating voltage need not be applied for these tests. The tests shall be performed on three samples, and the highest crest voltage recorded at the output terminals shall be less than the maximum peak voltage (voltage protection level plus peak overshoot). The response time shall also be less than 50 ns. For one-port type suppressors, input and output terminals are the same terminals. Where three-phase suppressors consist of three identical circuits, these tests need only be performed on one of the three circuits in each sample. If the suppressor discharge current exceeds 3000 amps, a resistance of up to 2 Ω may be added in series with the surge generator to limit the current after suppressor operation to 3000 amps.

10.3.1 *Fast-Front Impulse Suppression Tests*—A 1.2/50- μ s voltage impulse wave having a prospective crest voltage of 6-kV (5-kV/ μ s rate of rise) shall be used for the fast-front test. Five impulses of each polarity shall be applied to each set of terminals and the maximum peak voltage and response time obtained line to line and line to ground shall be recorded.

10.3.2 *Slow-Front Impulse Suppression Tests*—Slowfront tests shall be performed using a voltage impulse with a prospective crest of 4.5 kV and a wavefront (time from zero to crest) of 30 to 60 μ s (approximately 150-V/ μ s rate of rise). The time to half-crest value on the tail of the prospective waveform should be at least twice the wavefront time. Five impulses of each polarity shall be applied to each set of terminals and the maximum voltage and response time obtained line-to-line and line-to-ground shall be recorded.

10.4 *Voltage Protection Level Tests*—The purpose of this test is to determine the voltage protection provided by the suppressor when passing a surge current. The voltage protection level shall be measured at the output terminals of the suppressor using 8/20- μ s current impulse waveforms of both polarities applied to the input terminals. Three new specimens

(not previously surged) shall be subjected to five 1500-amp impulses of each polarity, followed by one 3000-amp surge of both polarities, applied between each set of input terminals and between each input terminal and ground. The time interval between current impulses shall not exceed 120 s. In the event that the input voltage developed by the current impulse generator exceeds 6 kV after the initial suppressor overshoot, the current impulse magnitude may be limited to a value which produces a 6-kV input voltage. The maximum value of line-to-line and line-to-ground voltage protection level at each current level shall be recorded and shall be less than the rated maximum suppression voltage rating. The range of voltage protection level values obtained with the series of 1500-amp impulses across the same set of terminals on any one unit shall not vary by more than 10 %.

10.5 *Duty Cycle Tests*—The duty cycle test establishes the ability of the suppressor to interrupt follow current successfully and repeatedly. Duty cycle tests shall be performed using one of the three suppressors previously used in the power frequency withstand tests. The suppressor shall be connected across a power supply within the tolerances of the nominal frequency. The power supply voltage, measured at the input terminals of the suppressor, shall be maintained as close as practicable to, but not less than, the rated maximum continuous operating voltage. The power supply shall have a short circuit capacity, measured at the suppressor input terminals, of at least 500 amps.

10.5.1 A series of ten 8/20- μ s current impulse waves with a crest value of 1500 A and constant polarity shall be applied line-to-line with a time interval between surges of 50 to 60 s. The first surge shall be timed to occur 30° after voltage, zero in the power-frequency half-cycle of the same polarity as the impulse. The second impulse will be timed to occur at 60°, and the timing will be increased an additional 30° for each subsequent surge. A second series of ten current impulses shall be applied line to ground, with the first surge of this series occurring within 2 min of the tenth line-to-line surge. The leakage current before the first impulse and immediately following the last impulse of each series of impulses and the suppression voltage rating during each surge shall be measured. The measured leakage currents shall be less than 30 mA. The leakage current following the last (tenth) impulse shall not have increased by more than 10 % of the value obtained before testing. The measured suppression voltage rating shall be less than the rated voltage protection level. The range of voltage suppression values obtained shall not vary by more than 10 %. If the voltage produced at the suppressor input terminals exceeds 6 kV, the current impulse magnitude can be limited to the value which results in a 6-kV input voltage. Where a three-phase unit consists of three identical circuits, or the peak overvoltages and clamping overvoltages determined by the previous tests are within 10 % for all three phases, only one line-to-line and one line-to-ground test need be performed.

10.6 *Life Cycle Tests*—Life cycle tests establish the ability of the suppressor to retain its voltage limiting function following exposure to a large number of impulses equivalent to the suppressor's life expectancy.

10.6.1 *Voltage Impulses*—Upon successful completion of the duty cycle tests, the suppressor selected for duty cycle testing shall have a series of 1000 voltage impulses with a 1.2/50- μ s waveshape and 6-kV magnitude applied between one phase and ground (or between the same two phases if no ground connection is used). Power frequency voltage need not be applied during these tests. If the suppressor discharge current for these tests exceeds 750 A, a resistance of up to 8 Ω may be added in series with the surge generator to limit the current after suppressor operation to 750 A. Surges shall be applied at 5-s intervals. Measurements of the maximum peak voltage (voltage protection level plus peak overshoot) shall be taken for the first ten surges and for the last ten surges. The average of the maximum peak voltage for the first ten surges and for the last ten surges shall not vary by more than 10 %.

10.6.2 *Current Impulses*—Following the 1000 voltage impulses, 1000 current impulses with an 8/20- μ s waveshape and 750-A magnitude shall be applied to the same set of terminals as were used for the 1000 voltage surges. If the voltage developed at the input terminals exceeds 6 kV, the current impulse magnitude may be limited to a value which produces an input voltage of 6 kV. Nominal frequency voltage shall be applied to the suppressor immediately before and for at least 10 s following application of the current impulse. Current surges shall be applied at 5-s intervals. The value of voltage protection level and the leakage current through the suppressor 10 s following the impulse shall be measured for the first ten surges and the last ten surges. The average of these two parameters for the first ten and last ten measurements shall not vary by more than 10 %.

10.7 *Load Current and Voltage Drop Tests*—For two-port surge suppressors, tests of the ampacity and voltage drop shall be conducted on one sample. A reduced voltage source may be used for the performance of these tests. For multi-phase suppressors, tests shall be performed using the assembled suppressor and the specified magnitude of test current shall be conducted through all phases simultaneously.

10.7.1 *Rated Current and Voltage Drop*—A current not less than the rated current of the suppressor shall be passed through the device (from “input” to “output” terminals) for a period of 1 h. The maximum voltage between corresponding input and output terminals shall be measured with rated current flowing through the suppressor at the end of the 1-h test period and shall not exceed 0.25 % of the nominal system voltage. The temperature rise of the suppressor case and any internal current-carrying components shall not exceed 20°C.

10.7.2 *Inrush Current*—A current equal to ten times rated current shall be passed through the suppressor (from input to output terminals) for ten cycles without loss of continuity (including interruption of fuses or other protective devices), causing the suppressor to shunt or limit current, or elevating the temperature of the suppressor or any of its current-carrying components by more than 20°C. Maximum continuous operating voltage shall be applied immediately following the application of the inrush current, and the measured leakage current shall be less than 30 mA.

11. Conformance and Production Tests

11.1 Conformance testing of a random sample may be requested by the purchaser to verify that selected performance characteristics demonstrated in the design tests have been maintained in the production suppressors supplied. These tests would not normally be performed unless specifically required. Production tests are routine tests performed on production units (or samples thereof) to ensure that basic safety requirements are met.

11.1.1 *Conformance Tests*—Conformance tests shall be performed only as required by the purchaser on a representative sample, selected at random, of the units supplied by the manufacturer. When required, testing shall be performed on the assembled suppressor. Sample size, testing required, and pass/fail criteria must all be specified by the purchaser. The following sample sizes and tests are suggested for conformance testing.

11.1.1.1 *Sample Size:*

No. Supplied	Test Sample Size
1–20	1
21–50	3
51–100	5
101 and above	5 % of total

11.1.1.2 *Power Frequency Test*—Each sample would be placed in an ambient temperature of at least 25°C, and the rated maximum continuous operating voltage would be applied for a period of two hours. Five cycles of 120 % of nominal system voltage for a period of 2 s, followed by 1 min at the maximum continuous operating voltage would then be applied. The leakage current at the beginning and end of this test would be measured to verify that it is less than the 30 mA rated leakage. Leakage current at the conclusion of the test should be less than 110 % of the initial leakage to demonstrate no permanent degradation. Additionally, the maximum continuous operating voltage should be applied between the line terminals and the ground connection for a period of 5 min. The leakage current after 5 min should be less than 30 mA and should not have increased by more than 10 % from the initial value at the beginning of the power frequency test.

11.1.1.3 *Impulse Voltage Test*—A single 1.2/50- μ s voltage impulse wave having a prospective crest voltage of 6 kV would be applied between each pair of input line terminals and between each input line terminal and ground for each sample. The maximum peak voltage and response time measured for each impulse should not exceed the rated maximum values.

11.1.1.4 *Impulse Current Test*—Each sample would be connected across a power supply with the nominal system voltage and frequency. A single 8/20- μ s current impulse with a peak amplitude of 750 A would be applied between one pair of input line terminals and between one line terminal and ground (selected at random) for each sample. If the voltage at the input terminals of the suppressor exceeds 6 kV, the amplitude of the current impulse could be reduced to that value which produces

an input voltage equal to, but not less than, 6 kV. The voltage protection level and response time at the output terminals and the suppressor leakage current would be measured and should be less than the rated maximum values.

11.1.2 *Production Tests:*

11.1.2.1 *Insulation Withstand*—Each suppressor shall withstand, without electrical breakdown, a voltage applied between the line terminals and the grounded case (including accessible dead metal parts). The voltage applied shall be 1000-V ac plus twice rated maximum continuous operating voltage for a period of 1 minute or 1200-V ac plus 2.4 times rated maximum continuous operating voltage for a period of 1 s. This test shall be performed when the suppressor is fully assembled. Alternatively, where the test voltage can damage solid-state components, the insulating structures of the suppressor may be tested before assembly of internal components, provided the test is representative of the completed suppressor and a random sample representing at least 1 % and at least three suppressors from the day's completed production are tested with any internal components which may be damaged by the test disconnected.

11.1.3 *Ground Continuity*—Each suppressor provided with a means for grounding (for example, ground terminal or pin) shall be tested using an ohmmeter, battery/buzzer circuit tester, or similar device to determine continuity between the grounding connection and all accessible dead metal parts.

12. Certification Requirements

12.1 When specified in the purchase order or contract, a producer's or supplier's certification shall be furnished to the purchaser that the material was manufactured, sampled, tested, and inspected in accordance with this specification and has been found to meet the requirements. When specified in the purchase order or contract, a report of the test results shall be furnished.

13. Marking Requirements

13.1 The product shall be labeled or tagged to show:

13.1.1 Manufacturer's name, model, serial number, and country of origin,

13.1.2 Product name,

13.1.3 Surge suppressor class and type,

13.1.4 Nominal rated voltage, current, frequency, and service,

13.1.5 Voltage protection level (in volts or kilovolts) for each protective mode.

14. Packaging Requirements

14.1 Product shall be packaged, boxed, crated, or wrapped to provide suitable protection during shipment and storage.

15. Keywords

15.1 ac power; circuits; surge current; surge suppression; surge suppressors; voltage transients

SUPPLEMENTARY REQUIREMENTS

The following supplementary requirements are applicable to Navy procurements and shall apply only when specified by the purchaser in the contract or purchase order.

S1. Performance

S1.1 The surge suppressors shall meet the performance requirements of 7.1 except for voltage protection level at 480 V and minimum life which shall be in accordance with Table S1.1. In addition, the surge suppressors shall meet the performance requirements for minimum energy capability and minimum average power capability specified in Table S1.1.

S2. Life Cycle Test Requirements

TABLE S1.1 Performance Requirements

Voltage Protection Level at 480 V	±1600 V
Minimum life	5000 operations
Minimum energy capability	450 J/phase
Minimum average power capability	2 W

S2.1 The surge suppressors shall meet all the life cycle requirements specified in 10.6 with the following exceptions:

S2.1.1 Number of applied voltage impulses as described in 10.6.1 shall be 2500. Surges shall be applied at 12-s intervals.

S2.1.2 Number of applied current impulses as described in 10.6.2 shall be 2500. Surges shall be applied at 12-s intervals.

S3. Testing—The supplier is responsible for the performance of all testing and inspections. Except as otherwise specified, the supplier may use his own facilities or any commercial laboratory acceptable to the Government. The Government may reserve the right to perform any of the testing or inspections set forth in the specification requirements. This testing shall assure qualification on a one-time basis unless the manufacturer makes a significant change in materials or process.

APPENDIX

(Nonmandatory Information)

X1. ADDITIONAL INFORMATION ON DESIGN AND PERFORMANCE CONSIDERATIONS

X1.1 *Shipboard Electrical Systems Environment:*

X1.1.1 Transient voltage surge suppressors (TVSS) devices work better and can more effectively shunt damaging transient overvoltages and current pulses to electronic equipment, if system grounding is done properly and has good integrity. Therein lies the major problem with TVSS devices for shipboard use. Unlike industrial or commercial electrical systems which have an ac supply ground and an equipment ground, most shipboard electrical systems are “ungrounded.” Without a system ground (normally referred to as the neutral or common), then shipboard TVSS devices have protective modes that are limited to line-to-line and/or line-to-ground shunting of transients. Equipment (safety) grounds are achieved by proper mounting of equipment to the ship’s metal hull or structure or installation of grounding straps between the hull and isolated equipment. The effectiveness of shipboard TVSS will be highly dependent on the equipment grounding techniques.

X1.2 *Single Component Versus Hybrid Transient Voltage Surge Suppressors:*

X1.2.1 Activated by transient voltage and current, a TVSS component redirects or shunts a portion of the transient current through the device and away from the load. A number of TVSS components are available with each having distinct advantages and disadvantages. These components consist of two basic types of protector: clamps and crowbars. Clamps (metal-oxide varistors and silicon avalanche suppressors) simply limit, while crowbars (gas tubes and carbon-block arrestors) exhibit steep negative resistance characteristics that result in voltage protection levels well below their striking potential.

X1.2.2 Hybrid transient voltage surge suppressors are designed to take advantage of several different types of components thereby enhancing overall performance and reliability. Hybrids usually incorporate a high energy capable, primary suppression section and tighter clamping, lower energy section. A hybrid design appears simple, however the proper component selection by the manufacturer is critical so that they function together as a coordinated system. A properly designed hybrid TVSS will vastly outperform any single component suppressor.

X1.3 *Series Versus Parallel Devices:*

X1.3.1 Surge suppressor components are inherently parallel or “across the line” components making them insensitive to load currents. However, because any impedance between the surge suppressor component and the transient-carrying line greatly reduces their effectiveness, lead length is an important consideration. The ideal one-port (parallel or shunt-connected) surge suppressor configuration is one with leads as short as possible. Longer leads, especially those excessive in length, may entirely negate the capability of the surge suppressor. Unfortunately, most transient voltage suppressors are parallel in design and require long wire-up leads.

X1.3.2 Series-connected (two-port) TVSS systems require load current sensitivity because all load currents pass through them. However, leads may be minimized in two-port designs, thereby significantly enhancing performance. Additionally, most two-port surge suppressors offer hybrid designs that incorporate multiple components and a coupling inductor.

X1.4 *Envelope Clamping Versus Sine Wave Clamping:*

X1.4.1 There are two main types of surge suppressors, envelope or threshold clamping devices and sine-wave clamping devices. Envelope devices, which represents the majority of surge suppressors available today, use only solid-state protection components such as metal oxide varistors (MOVs) or silicon avalanche diodes and operate by limiting or clamping the voltage across their terminals. This voltage protection level depends on the transient current and waveshape and must be chosen high enough not to interfere with the normal operation of the protected line.

X1.4.2 Envelope clamping devices are very effective at preventing transient damage from occurring to simple devices such as motors or power supplies, where insulation breakdown from high voltage would occur. They are not effective at keeping transient energy from low-voltage supplies to sensitive electronics or microprocessors.

X1.4.3 Sine-wave clamping suppressors consist of complex hybrid filter/suppressor circuits that effectively attenuates high frequency transients at whatever phase angle it occurs. Sine-wave clamping devices create lower clamping levels ensuring that any residual transient which propagates through low voltage power supplies is too small to cause circuit damage or logic disruption at the circuit board level.

X1.4.4 Although more costly than single-component or envelope (threshold clamping) devices, the use of hybrid surge suppressors that offer high-energy suppression, high-speed suppression and a EMI/RFI filter be adopted. Such devices should be installed at power distribution panels and critical electronic equipment and computers.

X1.5 *Networking Surge Suppressors:*

X1.5.1 Networking surge suppressors gives superior performance and reduced costs over the application of single devices. Suppression networks are built by distribution of components at more than one point within an electrical system. Networks do more than just protect more loads at more places; they actually improve the performance of individual components, by taking advantage of the wire's self-inductance between surge suppressors. Suppressor networks result in superior performance at a lower cost since the very best single point devices are no longer needed for effective protection.

X1.5.2 Networked surge suppressors reduce the amplitude of the transient step by step. The relationship of voltage protection level to current for suppression devices like MOVs is that the lower the current the lower the voltage protection level and, therefore the lower the residual voltage getting through to the load you are trying to protect. Transients act like waves in a transmission line. When the wave encounters a change of impedance (which occurs with the introduction of suppression component such as an MOV or silicon avalanche

diode), then a portion of the transient is reflected (bounces back) in the opposite direction with an opposite polarity. That portion of energy which finds its way in between two suppression devices separated by (wire) inductance, bounces back and forth until it is dissipated or escapes into other forms of energy.

X1.6 *Safety Features:*

X1.6.1 There is a fire hazard with surge suppressors. Surge suppressors can and do catch fire. Suppressors used to protect sensitive electronic equipment in home, office, industry, Naval and marine against transient voltages on ac circuits have failed in service, some overheating seriously, melting and even catching on fire. The theoretical cause has been debated and fire hazard tests proposed, however the most practical solution is to include provisions in the equipment design to preclude the devices catching fire. Those recommended for consideration by the purchaser would include:

X1.6.1.1 Enclosure shall be metallic.

X1.6.1.2 Two-port devices shall include a circuit breaker that interrupts all phases (and neutral where applicable) of the supply circuit.

X1.6.1.3 Thermal protection of TVSS shall interrupt supply circuit for overtemperature condition.

X1.6.1.4 Fail open circuit that automatically shuts off power to connected equipment in the event of a suppression component failure and protects equipment from being exposed to unfiltered "raw" power.

X1.6.2 Thermal failure modes of gapless, varistor-based surge suppressors is considered significantly more likely than failure to a surge suppressor during a large, single energy transient. Thermal failure involves thermal runaway from one of three sets of circumstances:

X1.6.2.1 Following a large transient that elevated the temperature of MOV beyond point of recoverable thermal equilibrium.

X1.6.2.2 During an extended temporary overvoltage (sometimes referred to as a "voltage swell").

X1.6.2.3 At the end of the life of a device previously exposed to repetitive temporary overvoltages or surges, when the rated number and magnitude of pulses for that device has been exceeded and the standby current has slowly increased to a point where thermal runaway develops.

X1.6.3 Surge suppressors, as recommended in this standard, should include a thermal cutoff device (in addition to an overcurrent protective device) that will sense the varistor temperature and interrupt the supply source during the initial part of the thermal runaway. In reality, the thermal failure modes of X1.6.2.1 and X1.6.2.2 may happen too fast for a cut-off device to act before terminal thermal runaway. The failure mode defined in X1.6.2.3 is the most preventable by a closely coupled cutoff device.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).