



Standard Specification for Tanks, 5 and 10-Gal (20 and 40-L) Lube Oil Dispensing¹

This standard is issued under the fixed designation F 670; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last approval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This specification covers the material, dimensions, and construction of 5 and 10-gal (20 and 40-L) tanks purchased to store and dispense lubricating oils. The tanks are industrial safety cans mounted on a T-bar bracket, complete with drip tray. .

1.2 The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

- A 36/A36M Specification for Carbon Structural Steel²
- A 108 Specification for Steel Bars, Carbon, Cold Finished, Standard Quality³
- A 164 Specification for Electrodeposited Coatings of Zinc on Steel⁴
- A 167 Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip⁵
- A 308 Specification for Steel Sheet, Cold-Rolled, Terne (Lead-Tin Alloy) Coated by the Hot-Dip Process⁶
- A 569/A569M Specification for Steel, Carbon (0.15 Maximum, Percent), Hot-Rolled Sheet and Strip Commercial Quality⁷

¹ This specification is under the jurisdiction of ASTM Committee F25 on Ships and Marine Technology and is the direct responsibility of Subcommittee F25.03 on Outfitting.

Current edition approved Dec. 10, 2002. Published January 2003. Originally approved in 1980. Last previous edition approved F 670 – 87 (1994) ^{ϵ 1}.

² *Annual Book of ASTM Standards*, Vol 01.04.

³ *Annual Book of ASTM Standards*, Vol 01.05.

⁴ Discontinued 1981—Replaced by B 633, *Annual Book of ASTM Standards*, Vol 02.05.

⁵ *Annual Book of ASTM Standards*, Vol 01.03.

⁶ *Annual Book of ASTM Standards*, Vol 01.06.

⁷ Discontinued 2000—Replaced by A 1011/A 1011M, *Annual Book of ASTM Standards*, Vol 01.03.

3. Ordering Information

3.1 Orders for tanks under this specification shall include the following:

3.1.1 Quantity (number),

3.1.2 Size, either 5 or 10 gal (20 or 40 L),

3.1.3 Purchase option for finished tank materials: Terne plate (4.1.3), and

3.1.4 ASTM designation and year of issue.

3.2 If only size, quantity, and ASTM designation are specified and no purchase options are specified, then suppliers shall furnish all stainless steel tanks, brass faucets with flash arrestors, and painted steel mounting columns with bolt-on drip tray assemblies, which include perforated steel tray liners, drain plugs, drilled mounting holes, and mounting bolts.

3.3 Optional packaging/shipping.

3.3.1 If required for shipping, tanks shall be packaged individually in cartons suitable for freight handling.

4. Materials and Manufacture

4.1 Materials:

4.1.1 *316 Stainless Steel Sheet* (Specification A 167), minimum thickness 24 gage (0.6 mm) on tank body, 22 gage (0.8 mm) on tank top and bottom; body bracket, filler spout, flash arrestor, vacuum breaker valve and linkage.

4.1.2 *316 Stainless Steel Cast, Wrought, or Forged Flanges*, (for faucet and drain).

4.1.3 *Terne Plate Sheet* (purchase option), minimum thickness 22 gage (0.8 mm) on tank body, top and bottom: body bracket, filler spout (Specification A 308).

4.1.4 Mild Steel:

4.1.4.1 *Bolt-On Column Stand*, T-section, hot-rolled (Specification A 36/A 36M); minimum thickness 0.160 in. (4 mm).

4.1.4.2 *Drip Tray Bracket*, round edge, hot-rolled (Specification A 569/A569M).


4.1.4.3 *Drip Tray Assembly*, hot or cold-rolled (Specification A 108).

4.1.4.4 *Drip Tray Liner*, 11-gage (3 mm), zinc-plated (Specification A 164).

4.1.4.5 *Filler Spout Cover*, zinc-plated steel (Specification A 164).

4.1.4.6 *Drip Tray Drain*, $\frac{3}{4}$ -in. (20 mm) NPS drain.

F 670 - 02



Dimensions	Size	A Height, in.	B Bolt Hole Spacing, in.	C Tank Height, in.	D Number of Bolt Holes	Weight, lb	
						Dry	Wet (Water)
	5-gal	22 1/2	10 1/2	9 7/8	3	39	81
	10-gal	33 3/4	10 1/2	20 7/8	4	49	132

Note 1—Dimensions and construction for guidance only.
 Note 2—1 in. = 25.4 mm.
 Note 3—1 lb = 0.4536 Kg.

FIG. 1 Dimension of Tank

4.1.5 Cast Brass:

4.1.5.1 *Faucet*, lever-lock, self-closing, 3/4-in. (20 mm) outside diameter, male threaded.⁸

4.1.5.2 *Drip Tray Drain Plug and Tank Bottom Drain Plug*, 3/4-in. (20 mm) NPS.

4.1.6 *Cast Aluminum*, self-closing, spring-action type, one-piece, filler spout cover lever.

4.2 *Manufacture*—All sheet metal seams shall be welded.

5. Dimensions and Weight

5.1 The dimensions in Fig. 1 are recommended nominal dimensions. Weights are estimated and are not critical. Volume of tanks shall be 5 and 10 gal (20 and 40 L), respectively.

⁸ Protectoseal 531G, available from The Protectoseal Co., 225 Foster Ave., Bensenville, IL 60106, or equivalent, has been found suitable for this purpose.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).

6. Workmanship, Finish, and Appearance

6.1 Workmanship on tank, stand, and drip pan shall be of sufficient quality to prevent dirt accumulation. Welding shall have small, even beading, free of slag and spatter. Surface of all castings shall be of uniform texture, without cracks, pitting, or flashing. Stand and drip tray shall have corners broken and all burrs removed.

6.2 Tank, column, bracket, and tray shall be covered with one coat 1.5 mils (0.05 mm) thick of a zinc rich primer. The stainless steel tank shall have no paint.

7. Testing Methods

7.1 Test each tank by subjecting to an internal air pressure of 5 psi (35 kPa) with no visible seam leakage when subjected to underwater or soap bubble test.

8. Keywords

8.1 lubricating oil tanks; marine; marine storage tanks; marine technology; oil dispensers; ships; tanks