

Designation: F 1667 – 02

Standard Specification for Driven Fasteners: Nails, Spikes, and Staples¹

This standard is issued under the fixed designation F 1667; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense. The Commercial and Government Entity (Cage) Code for ASTM: 81346.

1. Scope

1.1 This specification covers nails, spikes, staples, and other driven fasteners, as listed in Table 1.

Note 1—Fastener ductility information is presented in Table 2 and dimensional information in Tables 3-63.

1.2 Fasteners described in this specification are driven by hand tool, power tool, or mechanical device in single or multiple strikes and may be positioned for striking by hand, tool, or machine.

1.3 The values stated in inch-pound units are to be regarded as the standard.

1.4 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

2.1 ASTM Standards:

- A 153/A 153M Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware²
- A 510 Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel³
- A 641/A 641M Specification for Zinc-Coated (Galvanized) Carbon Steel Wire²
- B 695 Specification for Coatings of Zinc Mechanically Deposited on Iron and Steel⁴
- F 547 Terminology of Nails for Use with Wood and Wood-Base Materials⁵
- F 592 Terminology of Collated and Cohered Fasteners and Their Application Tools⁵

- ⁴ Annual Book of ASTM Standards, Vol 02.05.
- ⁵ Annual Book of ASTM Standards, Vol 01.08.

F 680 Test Methods for Nails⁵

F 1575 Test Method for Determining Bending Yield Moment of Nails⁵


3. Terminology

3.1 *Definitions*—The definitions used in this specification are those of common commercial acceptance and usage and also appear in Terminologies F 547 and F 592.

4. Classification

4.1 The fasteners and their Table 1 classification are identified as follows:

NOTE 2—The identification of fasteners, classified by style and type (alpha indicators) followed by a dash number (numerical code) based on Tables 3-63, identifies dimensions specifically and establishes a PIN (part identifying number) system when preceded by the F 1667 ASTM designator of this specification. For example:



^A All dimensions are given in inches.

4.2 The trade designation, *S*, pennyweight, used in commercial practice is referenced in Tables 3-63 wherever it applies.

5. Ordering Information

5.1 Orders for driven fasteners under this specification shall include the following information:

5.1.1 Quantity or weight;

5.1.2 Part identifying number (PIN) or product description (see 4.1 and appropriate table);

5.1.3 Special material requirements, if specified, including coatings or finishes;

- 5.1.4 ASTM designation;
- 5.1.5 Packaging requirements;

Copyright © ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States.

¹ This specification is under the jurisdiction of ASTM Committee F16 on Fasteners and is the direct responsibility of Subcommittee F16.05 on Driven and Other Fasteners.

Current edition approved April 10, 2002. Published April 2002. Originally published as F 1667–95. Last previous edition F 1667–01a.

² Annual Book of ASTM Standards, Vol 01.06.

³ Annual Book of ASTM Standards, Vol 01.03.

€¶)≯	F	166	67
------	---	-----	----

TABLE 1 Classification and Identification Index

TABLE 1	Clas	sification and Ider	ntification Index	
Туре		Style	Style Identification	Table
I-Nails (NL)	1.	Brads	BR	3
· · · ·	2.	Barrel	BL	4
	3.	Boat	BTH/BTL	5
	4.	Box A	BXA	6
		Box B	BXB	7
	5.	Broom	BM	8
	6.	Casing	CN	9
	7.	Cooler	CL	10
	8.	Sinker	SK	11
	9.	Corker	CK	12
	10.	Common	CMA	13
		Common	CMC	14
		Common	CMS	15
		Common	CMM	16
	11.	Concrete	CTS/CTM	17
	12.	Double-headed	DH	18
	13.	Fine	FN	19
	14.	Finishing	FH	20
	15.	Flooring	FL	21
	16.	Lath	LHF	22
		Lath	LHH	23
	17.	Masonry	MR/MRH	24
	18.	Pallet	PL	25
	19.	Gypsum wallboard	GWS	26
		Gypsum wallboard	GWM	27
	20.	Roofing	RFA	28
		Roofing	RFS	29
		Roofing	RFC	30
		Roofing	RFL	31
		Roofing	RFR	32
		Roofing	RFD	33
		Roofing	RFNS/RFND	34
	21.	Shingle	SHAD/SHAS	35
		Shingle	SHSS/SHNSB	36
	22.	Siding	SDF/SDC/SDK	37
	23.	Slating	SLA/SLC/SLS	38
	24.	Rubber heel	RH	39
	25.	Underlayment	UL	40
	26.	Square-barbed	SB	41
	27.	Masonry drive	MD	42
	28.	Escutcheon	ES	43
	29.	Glulam rivet	GR	44
II—Cut nails (CN)	1.	Common	CM	45
	2.	Basket	BK	46
	3.	Clout	CL	47
	4.	Trunk	TR	48
	5.	Cobblers	CB	49
	6.	Extra-iron clinching	EC	50
	7.	Hob	HB	51
III—Spikes (SP)	1.	Common	CM	52
	2.	Gutter	GRF/GRO	53
	3.	Round	RDC/RDF	54
	4.	Barge and boat	BB	55
IV—Staples (ST)	1.	Fence	FN	56
,	2.	Poultry netting	PN	57
	3.	Flat top crown	FC	58
		Flat top crown	FCC	59
	4.	Round or V crown	RC	60
	5.	Preformed	PC	61
	6.	Electrical	RE	62
	7.	Preformed hoop	PH	63

5.1.6 A producer's or supplier's certification that the material and the finished fastener are in compliance with this specification, furnished only when specified in the purchase order;

5.1.7 Supplementary requirements, if any; and

5.1.8 Any additions agreed upon between the purchaser and the supplier.

6. Material Requirements

6.1 Steel wire used in the manufacture of driven fasteners

TABLE 2 Bend Angles for Fasteners Using the Test Methods F 680 Bend Test

	Fastener Material	Bend Angle, °
1.	Steel wire: (low-carbon, medium-low carbon, medium-carbon) (unhardened)	180
2.	Stainless steel wire	180
3.	Hardened steel fasteners	20
4.	Sheet steel for cut nails, Type II, and cut spikes, Type III	90
5.	Copper (min 98 %)	180
6.	Copper clad wire (min 20 %)	180
7.	Aluminum alloy wire	90
8.	Brass wire	180

shall be of low carbon, medium-low carbon, or medium-high carbon.

6.2 Stainless steel wire used in the manufacture of driven fasteners shall be of Types 302, 304, 305, or 316.

6.3 Carbon steel wire for the manufacture of hardened steel nails shall be suitable for heat treatment to a minimum hardness of 37 HRC.

6.4 Sheet steel used in the manufacture of cut nails (Type II) and cut spikes (Type III) shall be a medium-carbon sheet steel.

6.5 Copper used in the manufacture of driven fasteners shall contain a minimum of 98 % pure copper.

6.6 Copper-clad steel wire used in the manufacture of driven fasteners shall contain not less than 20 % copper by weight. The average thickness of copper on the steel wire shall be not less than 10 % of the radius of the clad wire; the minimum thickness of copper on the steel wire shall be not less than 8 % of the radius of the clad wire.

6.7 Aluminum alloy wire used in the manufacture of fasteners shall conform to Alloy 2024, 5056, 6061, or 6110 and have a minimum ultimate tensile strength of 60 000 psi.

NOTE 3—Smooth shank nails are sometimes chemically treated to remove grease, oil, and foreign matter and to roughen the surface microscopically. Mechanically deformed nails are sometimes cleaned to remove grease and foreign matter.

6.8 Brass wire used in the manufacture of fasteners shall be of good commercial quality suitable for the purpose.

7. Physical Properties

7.1 *Ductility*—The fasteners shall be sufficiently ductile to withstand cold bending without fracture, as specified in Table 2 for various materials used in the manufacture of fasteners utilizing the conventional bend test described in Test Methods F 680. Mandrel diameter used in this test shall not exceed nail/wire diameter. The cold bend test shall not apply to unhardened nails with deformed shanks.

7.2 *Tensile Strength*—Finished driven fasteners are not normally subject to tension testing. However, the wire or sheet used to manufacture the fastener is tested as required for control in the production process during manufacture.


8. Dimensions and Tolerances

8.1 Nominal dimensions of nails and spikes shall be as shown in Tables 3-55. The following dimensional designations shall apply:

∰ F 1667

TABLE 3 Type I, Style 1-Brads^A

Note—Steel wire, brad head, diamond point, round smooth shank, bright finish. When specified, brads shall have a modified brad head with a blunt or chiseled point for use with mechanical drivers.



Dash No.	L	D	S	No./lb	Dash No.	L	D	S	No./It
01	3/8	0.035		9520	21	13/4	0.062		670
02	1/2	0.035		7060	22	13/4	0.080		400
03	1/2	0.048		3990	23	13/4	0.099	5d	270
04	5/8	0.035		5680	24	2	0.062		580
05	⁵ /8	0.048		3200	25	2	0.080		350
06	3/4	0.035		4800	26	2	0.113	6d	180
07	3/4	0.048		2620	27	21/4	0.080		320
08	3/4	0.062		1550	28	21/4	0.113	7d	160
09	7/8	0.035		4220	29	21/2	0.080		290
10	7/8	0.048		2220	30	21/2	0.131	8d	110
11	7/8	0.062		1280	31	23/4	0.131	9d	97
12	1	0.054		1500	32	3	0.148	10d	70
13	1	0.062		1120	33	31/4	0.148	12d	65
14	1	0.072		904	34	31/2	0.162	16d	50
15	11/4	0.054		1210	35	4	0.192	20d	31
16	11/4	0.062		940	36	41/2	0.207	30d	24
17	11⁄4	0.080	3d	560	37	5	0.225	40d	18
18	11/2	0.054		1040	38	51/2	0.244	50d	14
19	11/2	0.080	· · ·	470	39	6	0.262	60d	11
20	11/2	0.099	4d	320					

^A All dimensions are given in inches.

S = trade designation (reference in penny weight),

L = length, in.,

H = head diameter or width, in.,

D = shank diameter, in.,

B = head separation, in. (Table 18), and

No./lb = approximate count per pound.

8.1.1 The lengths, *L*, of nails and spikes with flat heads or parallel shoulders under the head shall be measured from under the head or shoulder to the tip of the point. All other nails and spikes shall be measured overall.

8.1.2 The diameter, D, of smooth shank nails and spikes shall be measured away from the gripper marks. The diameter, D, of formed or deformed shanks shall be measured before deformation, or, if specified, the thread crest diameter after deformation, or both. All diameter dimensions shall be taken prior to the application of or after the removal of any coatings or finish.

8.2 Tolerances on Nominal Dimensions for Nails and Spikes:

8.2.1 Length tolerances shall be $\pm \frac{1}{32}$ in. for lengths up to and including 1 in.; $\pm \frac{1}{16}$ in. for lengths over 1 in., up to and including $2\frac{1}{2}$ in.; $\pm \frac{3}{32}$ for lengths over $2\frac{1}{2}$ in., up to and including 7 in.; and $\pm \frac{1}{8}$ in. for all lengths over 7 in.

8.2.2 Shank diameter tolerances shall be ± 0.002 in. for diameters smaller than 0.076 in. and ± 0.004 in. for diameters 0.076 in. and larger.

8.2.3 Head Diameter Tolerances:

8.2.3.1 *Hand Driven*—Tolerances on head diameters of roofing nails shall be ± 0 , -10 % of the nominal head diameter (the mean of two readings 90° apart). For other brads, nails, and spikes, the tolerance shall be ± 10 % of the nominal head diameter (individual measurement). The difference in diameter across the long axis of a roofing nail shall not exceed that across the short axis by more than 20 %. For other brads, nails, and spikes, the difference in diameter across the long axis shall not exceed that across the short axis by more than 20 %. For other brads, nails, and spikes, the difference in diameter across the long axis shall not exceed that across the short axis by more than 10 %. A fillet shall be provided under the head if not otherwise specified.

8.2.3.2 *Power Driven*—Tolerances on head diameters of power-driven nails shall comply with the manufacturer's specifications and shall be suitable for use in the make and model of the tool specified.


8.3 Nominal dimensions of staples shall be as shown in Tables 56-63, and the following dimensional designations shall apply:

8.3.1 Hand Tool–Driven Nominal Dimensions:

∰ F 1667

TABLE 4 Type I, Style 2-Barrel Nails^A

Note-Steel wire, flat head, diamond point, round smooth shank, bright, zinc or cement coated as specified.





Dash No.	L	D	н	No./lb	Dash No.	L	D	н	No./Ib
01	5/8	0.067	0.148	1.550	05	11/8	0.076	0.177	670
02	3/4	0.067	0.148	1.300	06	11/4	0.080	0.188	540
03	7/8	0.076	0.177	850	07	1³⁄a	0.092	0.219	380
04	1	0.076	0.177	750	08	11/2	0.092	0.219	350

All dimensions are given in inches.

TABLE 5 Type I, Style 3—Boat nails^A

Note-Steel wire, oval countersunk head, chisel point, round smooth shank, bright or zinc coated as specified.





		F 1667	NLBTL								
Dash No.	S	L	D	н	No./lb	Dash No.	S	L	D	н	No./Ib
01	4d	11/2	0.188	0.406	82	01	4d	11/2	0.250	0.500	47
02	6d	2	0.188	0.406	62	02	6d	2	0.250	0.500	36
03	8d	21/2	0.188	0.406	50	03	8d	21/2	0.250	0.500	29
04	10d	3	0.250	0.500	24	04	10d	3	0.375	0.750	11
05	12d	31/4	0.250	0.500	22	05	12d	31/4	0.375	0.750	10
06	16d	31/2	0.250	0.500	20	06	16d	31/2	0.375	0.750	9
07	20d	4	0.250	0.500	18	07	20d	4	0.375	0.750	8

All dimensions are given in inches.

L = leg length, inside, in.,

D = round leg diameter, in.,

C = crown width, inside, in., and

No./lb = approximate count per pound.

8.3.2 Power Tool–Driven Nominal Dimensions:


- D = round leg diameter, in.,
- L = leg length, outside, in.,
- T = leg thickness, in. (see Table 57),
- W = leg width, in. (see Table 57),
- C = crown width, outside, in., and

G = steel wire gage.

∰ F 1667

TABLE 6 Type I, Style 4A-Box Nails^A

Note—Steel wire, flat head, diamond point, round, barbed or smooth shank, bright or cement coated as specified. When specified, box nails shall have an altered or T-head with a diamond, blunt, or chisel point for use with mechanical drivers.




						NCD/01					
Dash No.	S	L	D	н	No./lb	Dash No.	S	L	D	н	No./Ib
01	2d	1	0.067	0.188	940	08	9d	23/4	0.113	0.297	120
02	3d	11/4	0.076	0.219	590	09	10d	3	0.128	0.312	90
03	4d	11/2	0.080	0.219	450	10	12d	31/4	0.128	0.312	83
04	5d	13⁄4	0.080	0.219	390	11	16d	31/2	0.135	0.344	69
05	6d	2	0.099	0.266	220	12	20d	4	0.148	0.375	50
06	7d	21/4	0.099	0.266	200	13	30d	41/2	0.148	0.375	45
07	8d	21/2	0.113	0.297	140	14	40d	5	0.162	0.406	34

A All dimensions are given in inches.

TABLE 7 Type I, Style 4B-Box Nails^A

Note-Steel wire, flat head, diamond point, round smooth shank, cement coated.



	F 1667 NLBXB												
Dash No.	S	L	D	н	No./lb	Dash No.	S	L	D	н	No./Ib		
01	2d	1	0.058	0.172	1250	06	7d	21/8	0.086	0.250	280		
02	3d	11/8	0.062	0.188	980	07	8d	2 ³ /8	0.099	0.266	190		
03	4d	13/8	0.067	0.203	680	08	9d	25/s	0.099	0.266	170		
04	5d	15⁄8	0.072	0.219	510	09	10d	27/a	0.113	0.297	120		
05	6d	17⁄8	0.086	0.250	315								

^A All dimensions are given in inches.

8.4 Tolerances on Nominal Dimensions for Staples:

8.4.1 Leg length, *L*, tolerances shall be $+\frac{1}{32}$, $-\frac{1}{64}$ in. for both hand tool–driven and power tool–driven staples.

8.4.2 Diameter tolerances for hand tool–driven round staples shall be ± 0.002 in. for diameters smaller than 0.076 in. and ± 0.004 in. for diameters 0.076 in. and larger.

8.4.3 Thickness and width tolerances on power-driven staples shall comply with the manufacturer's specification and

shall be suitable for use in the make and model tool specified (see Tables 55-62).


8.4.4 Crown width tolerances are $\pm \frac{1}{32}$ in. unless otherwise specified.

8.5 Nominal Dimensions for Cut Nails, Type II—Unless otherwise specified, cut nails shall be sheared from medium carbon sheet steel and shall have a wedge-shaped shank with a sheared square point end narrower than the upset head end. The

F 1667

TABLE 8 Type I, Style 5-Broom Nails^A

Note-Steel wire, flat or star head, diamond point, round smooth shank, bright finish, as specified.




Dash No.	L	D	Н	No./Ib
01	5/8	0.072	0.203	1480
02	5/8	0.080	0.219	990
03	3/4	0.072	0.203	1170
04	3/4	0.080	0.219	840

A All dimensions are given in inches.

TABLE 9 Type I, Style 6—Casing Nails^A

Note-Steel wire, flat countersunk cupped head, diamond point, round smooth shank, bright finish.



ΙE

Dash No. s L D н No./lb Dash No. S L D н No./lb 0.099 21/2 0.113 0.155 150 01 2d 0.067 1090 07 8d 1 02 3d 11/4 0.076 0.113 650 08 9d 23/4 0.113 0.155 135 03 4d 0.080 0.120 490 09 10d 3 0.128 0.170 95 11/2 04 5d 0.080 0.120 415 10 12d 31/4 0.128 0.170 90 13/4 05 0.099 16d 0.135 6d 0.142 245 31/2 0.177 75 2 11 06 0.099 0.142 215 7d 21/4

All dimensions are given in inches.

designation T in Tables 45-50 refers to sheet thickness in finished product. Other designations shall be the same as those for nails in 8.1.

8.6 When gage is used for a nominal diameter dimension in the application of this specification, it shall be in accordance with the decimal equivalents as shown in Specification A 510, unless otherwise specified.

9. Workmanship

9.1 Fasteners covered by this specification shall be true to shape, well-finished, free from imperfections, clean, and free of corrosion. Mechanically driven collated items shall be uniform

and aligned properly in their assembled form for use in power tools.

10. Protective Coatings and Finishes


10.1 Zinc Coating:

10.1.1 Driven fasteners required to be zinc coated shall be cut and formed from hot-dip, hard-wiped, galvanized steel wire, electrogalvanized steel wire, or zinc flake/chromate dispersion-coated steel wire; or they shall be cut from uncoated (bright) steel wire and shall be hot-dip galvanized, electrodeposited zinc coated, mechanically deposited zinc coated, or

∰ F 1667

TABLE 10 Type I, Style 7-Cooler Nails^A


Note—Steel wire, flat head, diamond point, round smooth shank, cement coated. When specified, coolers shall have an altered or T-head for use with mechanical drivers.



All dimensions are given in inches.



NOTE—Steel wire, flat countersunk head, diamond point, round smooth shank, bright or cement coated. When specified, sinkers shall have an altered or T-head for use with mechanical drivers.



All dimensions are given in inches.

zinc flake/chromate dispersion coated after forming. Powerdriven staples are not normally zinc coated after forming.

10.1.2 Hot-dip galvanized or electrogalvanized steel wire for the manufacture of fasteners shall have a coating weight in accordance with Specification A 641, Supplementary Requirements, Class 1.


10.1.3 Hot-dip galvanized steel fasteners coated after forming shall have a coating weight in accordance with Specification A 153, Class D, when a heavier coating for exterior use is specified. If not otherwise specified, the coating weight shall be in accordance with Specification A 641, Supplementary Requirements, Class 1.

10.1.4 Mechanically deposited zinc coatings applied to fasteners after forming shall have a thickness in accordance with Specification B 695, Class 40, unless otherwise specified. 10.2 Other Coatings and Finishes (When Specified):

F 1667

TABLE 12 Type I, Style 9-Corker Nails^A


NOTE-Steel wire, flat countersunk head, diamond point, round smooth shank, cement coated. When specified, corkers shall have an altered or T-head for use with mechanical drivers.



All dimensions are given in inches.

TABLE 13 Type I, Style 10—Common Nails^A

NOTE-Aluminum alloy wire, flat head, diamond point, round smooth shank, or, when specified, square barbed shank.



10d

16d

20d

04

05

06

8d All dimensions are given in inches.

s

4d

6d

Dash No.

01

02

03

10.2.1 Cement coating shall be applied by tumbling, mechanical dispensing device, or immersion in resin or other similar material and shall not be tacky or gummy. Cement coatings on power-driven fasteners shall be uniform and may be applied before, during, or after the fasteners are cohered into strips, clips, or coils.

11/2

21/2

2

0.099

0.120

0.148

0.250

0.266

0.281

830

430

220

NOTE 4-Cement coatings increase the holding strength in withdrawal of a driven fastener, depending on the fastener size, amount of cement coating applied, and method of driving.

10.2.2 Chemical etching shall remove the polish of fabrication and roughen the surface microscopically.

0.162

0.177

0.199

0.312

0.344 0.406 170

120

78

10.2.3 Blued nails shall be heated to form a thin, colored oxide on the surface.

10.2.4 Miscellaneous finishes, such as tin plating, liquor, brass plating, copper plating, phosphate coating, or oil coating shall be applied.

10.3 Altered Shapes and Deformations:

3

4


31/2


10.3.1 Mechanically formed or deformed nail shanks shall

∰ F 1667

TABLE 14 Type I, Style 10-Common Nails^A

NOTE-Copper wire, flat head, diamond point, round smooth shank.






				F 1667	NLCMC				
Dash No.	L	D	н	No./Ib	Dash No.	Ļ	D	н	No./Ib
01	5/8	0.065	0.156	1380	10	2	0.120	0.266	130
02	3/4	0.065	0.156	1160	11	2	0.134	0.281	
03	3/4	0.072	0.172	960	12	21/2	0.134	0.281	86
04	7/8	0.072	0.172	810	13	3	0.148	0.312	56
05	1	0.072	0.172	700	14	31/2	0.165	0.344	40
06	11/4	0.083	0.203	420	15	4	0.203	0.406	23
07	11/2	0.109	0.250	210	16	41/2	0.220	0.438	18
08	13/4	0.109	0.250	180	17	5	0.238	0.469	14
09	13/4	0.120	0.266	140	18	6	0.284	0.531	8

All dimensions are given in inches.

TABLE 15 Type I, Style 10—Common Nails^A

Note-Steel wire, flat head, diamond point, round smooth shank, bright, zinc or cement coated as specified.





					F 1667	NLCMS					
Dash No.	S	L	D	н	No./lb	Dash No.	S	L	D	н	No./Ib
01	2d	1	0.072	0.172	850	09	10d	3	0.148	0.312	66
02	3d	11/4	0.080	0.203	540	10	12d	31/4	0.148	0.312	61
03	4d	11/2	0.099	0.250	290	11	16d	31/2	0.162	0.344	47
04	5d	13⁄4	0.099	0.250	250	12	20d	4	0.192	0.406	30
05	6d	2	0.113	0.266	170	13	30d	41/2	0.207	0.438	23
06	7d	21/4	0.113	0.266	150	14	40d	5	0.226	0.469	17
07	8d	21/2	0.131	0.281	100	15	50d	51/2	0.244	0.500	14
08	9d	23/4	0.131	0.281	92	16	60d	6	0.262	0.531	11


All dimensions are given in inches


have barbs, flutes, threads, or angular serrations formed onto the wire from which the nail is manufactured. Mechanically deformed shanks shall have vertical or helical flutes or screwtype or annular (ring)-type deformations rolled onto the shank. Symmetrical helical shank deformations shall be obtained by twisting square wire. The deformations shall pass entirely around the shank body, resulting in expanded ridges and depressions. Nails with formed or deformed shanks may be


∰ F 1667

TABLE 16 Type I, Style 10-Common Nails^A

Note—Aluminum alloy wire, or steel wire, (bright, zinc coated or cement coated), altered or T-head, diamond or chisel point, round smooth shank, as specified. For use with mechanical drivers.







				F 1667 NLCMM		· · · · · · · · · · · · · · · · · · ·		
Dash No.	L	D	Dash No.	L	D	Dash No.	L	D
01	11/4	0.080	14	13/4	0.080	27	2	0.099
02	11/4	0.086	15	13/4	0.086	28	2	0.113
03	11/4	0.092	16	13/4	0.092	29	2	0.148
04	11/4	0.099	17	13⁄4	0.099	30	21/4	0.092
05	11/2	0.080	18	13⁄4	0.113	31	21/4	0.099
06	11/2	0.086	19	17/8	0.080	32	21/4	0.113
07	11/2	0.092	20	17/8	0.086	33	21/2	0.092
08	11/2	0.099	21	17/8	0.092	34	21/2	0.099
09	11/2	0.113	22	17⁄8	0.099	35	21/2	0.113
10	15/s	0.080	23	17/8	0.113	36	21/2	0.131
11	15/8	0.086	24	2	0.080	37	31/2	0.131
12	15/8	0.092	25	2	0.086			
13	15⁄a	0.099	26	2	0.092			

All dimensions are given in inches.

fabricated from round or square wire.

10.3.2 Mechanically formed or deformed nail heads shall be round or T-headed; or they shall be altered round for suitable use in a given make and model of a power-driving fastening system.

10.3.3 Staples manufactured for intended use in power tools shall comply with the tool manufacturer's specification or Type IV, Style 3 (Table 58 or Table 59).

11. Certification

11.1 When specified in the purchase order, a producer's or supplier's certification shall be furnished to the purchaser, indicating that the fasteners are in compliance with this specification and the purchase order.

12. Packaging and Package Marking

12.1 Unless otherwise specified, fasteners shall be in substantial commercial containers of the type, size, and kind commonly used for the purpose, so constructed as to preserve the contents in good condition and to ensure acceptance and safe delivery by common or other carriers to the point of delivery. In addition, the containers shall be so made that the contents can be removed partially without destroying the container's ability to serve as a receptacle for the remainder of the contents.

12.2 When specified, individual packages and shipping containers shall be marked with the part-identifying number and type, length, diameter (or gage, as applicable) of the fastener, the name of the manufacturer or distributor, and the quantity or net weight.


13. Keywords

13.1 diameter; driven fasteners; head; length; nails; point; spikes; staples

∰ F 1667

TABLE 17 Type I, Style 11-Concrete Nails^A

Note—Harded steel, flat countersunk head, diamond point, smooth or mechanically deformed shank formed from round or square stock, as specified, bright finish.





				F 1667	NLCTM				
Dash No.	L	D	н	No./Ib	Dash No.	L	D	н	No./Ib
01	3/4	0.181	0.284	240	05	2	0.181	0.284	93
02	1	0.181	0.284	204	06	21/2	0.181	0.284	68
03	11/2	0.181	0.284	116	07	23/4	0.181	0.284	60
04	13/4	0.181	0.284	112	08	3	0.181	0.284	52

A All dimensions are given in inches.

TABLE 18 Type I, Style 12—Double-Headed Nails^A

NOTE-Steel wire, flat heads, diamond point, round smooth shank, bright finish or cement coated.






Dash No.	S	L	D	B	No./lb	Dash No.	S	L	D	В	No./lb
01	6d	13/4	0.113	1/4	160	04	16d	3	0.162	3/8	45
02	8d	21/4	0.131	1/4	90	05	20d	31/2	0.192	3/8	28
03	10d	23/4	0.148	5/16	59	06	30d	4	0.207	7/18	22

🕼 F 1667

TABLE 19 Type I, Style 13—Fine Nails^A


NOTE-Steel or copper wire, flat head, diamond point, round smooth shank, bright finish.



All dimensions are given in inches.

TABLE 20 Type I, Style 14—Finish Nails^A

Note—Steel wire, brad head, altered or clipped T-head for use with mechanical drivers, diamond or chisel point, smooth or barbed shank formed from round or square stock, as specified, bright finished.



0-----


TP

Dash No.	S	L	D	Н	No./lb	Dash No.	S	L	D	Н	No./Ib
01	2d	1	0.058	0.086	1.470	07	8d	21/2	0.099	0.142	190
02	3d	11/4	0.067	0.099	880	08	9d	23/4	0.099	0.142	180
03	4d	11/2	0.072	0.106	630	09	10d	3	0.113	0.155	120
04	5d	13/4	0.072	0.106	530	10	12d	31/4	0.113	0.155	110
05	6d	2	0.092	0.135	290	11	16d	31/2	0.120	0.162	93
06	7d	21/4	0.092	0.135	250	12	20d	4	0.135	0.177	65

€∰ F 1667

TABLE 21 Type I, Style 15—Flooring Nails^A

Note—Harded steel or steel wire, casing head or flat-cupped countersunk head, diamond or blunt point, round, smooth or mechanically deformed shank, dark (hardened), bright (steel wire) or cement coated, as specified.




A All dimensions are given in inches.

TABLE 22 Type I, Style 16—Lath Nails^A

NOTE-Steel wire, flat head, diamond point, round smooth shank, blued finish.

3d



0.072

0.172

760

11/8


^A All dimensions are given in inches.

03

∰ F 1667

TABLE 23 Type I, Style 16—Lath Nails^A


Note-Steel wire, flat hook-head, diamond point, round smooth shank, bright, blued, or zinc coated as specified.




∰ F 1667

TABLE 24 Type I, Style 17—Masonry Nails^A

Note-Hardened steel, flat or flat countersunk head, diamond point, mechanically deformed shank, bright finish.






				F 166	7 NLMR				
Dash No.	L	D	Н	No./Ib	Dash No.	L	D	Н	No./Ib
01	1/2	0.148	0.312	340	09	21/2	0.148	0.312	76
02	3/4	0.148	0.312	280	10	23/4	0.148	0.312	70
03	1	0.148	0.312	170	11	3	0.148	0.312	67
04	11/4	0.148	0.312	140	12	31/4	0.148	0.312	60
05	11/2	0.148	0.312	130	13	31/2	0.162	0.344	48
06	13/4	0.148	0.312	110	14	33/4	0.162	0.344	45
07	2	0.148	0.312	98	15	4	0.177	0.375	35
08	21/4	0.148	0.312	84					
		- <u></u>		F 1667	NLMRH				
Dash No.	L	D	н	No./Ib	Dash No.	L	D	н	No./lb
01	1	0.250	0.562	63	05	2	0.250	0.562	34
02	11/4	0.250	0.562	47	06	21/2	0.250	0.562	27
03	11/2	0.250	0.562	43	07	31/2	0.250	0.562	19
04	13/4	0.250	0.562	39	08	3	0.250	0.562	24



TABLE 25 Type I, Style 18—Pallet Nails^A

Note—Hardened steel or steel wire (for mechanical drivers), flat head, altered or T-Head (for mechanical drivers), diamond point, round, mechanically deformed shank, bright finish (steel wire), or dark (hardened), as specified.



111


Dash No.	L	D	н	No./ib	Dash No.	L	D	н	No./It
01	11/2	0.120	0.281	190	11	31/4	0.148	0.312	61
02	1 ⁵ ⁄8	0.120	0.281	170	12	31/2	0.148	0.312	57
03	2	0.120	0.281	140	13	31⁄2	0.162	0.375	47
04	21/4	0.120	0.281	130	14	31⁄2	0.177	0.438	38
05	21/2	0.120	0.281	120	15	4	0.177	0.438	35
06	21/2	0.135	0.312	93	16	4	0.177	0.375	35
07	3	0.120	0.281	98	17	5	0.177	0.375	27
08	3	0.135	0.312	79	18	6	0.177	0.375	23
09	3	0.148	0.312	66	19	7	0.207	0.500	15
10	31/4	0.135	0.312	73	20	8	0.207	0.500	13

OGGGGGGG

A All dimensions are given in inches.

TABLE 26 Type I, Style 19—Gypsum-Wallboard, Gypsumboard, and Drywall Nails^A

Note-Steel wire, flat head, diamond point, round smooth or deformed shank, bright or blued finish.



	F 1667 NLGWS										
Dash No.	L	D	Н	No./lb							
01	11/8	0.092	0.297	470							
02	11/8	0.092	0.375	450							
03	11/4	0.092	0.297	420							
04	11/4	0.106	0.375	310							
05	13⁄4	0.092	0.375	290							

^A All dimensions are given in inches.

∰ F 1667

TABLE 27 Type I, Style 19—Gypsum-Wallboard, Gypsumboard, and Drywall Nails^A


Note-Steel wire, flat slightly countersunk head, long diamond point, round mechanically deformed shank, bright or blued finish.

	F 1667 NLGWM										
Dash No.	L	D	Н	No./lb							
01	11/8	0.099	0.250	380							
02	11/4	0.099	0.250	340							
03	13/8	0.099	0.250	320							
04	11/2	0.099	0.250	290							
05	15⁄8	0.099	0.250	270							

A All dimensions are given in inches.

TABLE 28 Type I, Style 20-Roofing Nails^A

Note-Aluminum alloy wire, flat head, diamond point, round smooth shank, or, when specified, square-barbed shank.




	F 1667 NLRFA												
Dash No.	L	D	н	No./Ib	Dash No.	L	D	н	No./lb				
01	3/4	0.120	0.438	940	08	11/4	0.120	0.438	620				
02	3/4	0.135	0.438	750	09	11/4	0.135	0.438	490				
03	7/8	0.120	0.438	830	10	11/2	0.120	0.438	520				
04	7/8	0.135	0.438	660	11	11/2	0.135	0.438	420				
05	1	0.120	0.438	700	12	13⁄4	0.135	0.438	370				
06	1	0.135	0.438	600	13	2	0.135	0.438	340				
07	1	0.135	0.438	580	14	21/2	0.145	0.438	230				

🕼 F 1667

TABLE 29 Type I, Style 20—Roofing Nails^A

Note—Steel wire, flat head, diamond point, round, smooth or barbed shank, bright or zinc coated, as specified, for hand driving or for use with mechanical drivers.




					NLRFS				
Dash No.	L	D	Н	No./Ib	Dash No.	L	D	Н	No./lb
01	3/4	0.106	0.375	460	29	11⁄4	0.120	0.312	240
02	3/4	0.120	0.438	340	30	11/4	0.120	0.438	220
03	3/4	0.135	0.469	270	31	11⁄4	0.120	0.500	
04	3/4	0.142	0.484	240	32	11/4	0.135	0.469	180
05	3/4	0.148	0.500	220	33	11/4	0.142	0.484	160
06	3/4	0.162	0.500	200	34	11⁄4	0.148	0.500	140
07	7/8	0.106	0.375		35	11/4	0.162	0.500	120
08	7/8	0.120	0.438	300	36	11/2	0.106	0.375	
09	7/8	0.120	0.500	250	37	11/2	0.120	0.438	180
10	7/8	0.135	0.469	240	38	11/2	0.120	0.500	160
11	7/8	0.142	0.484	210	39	11⁄2	0.135	0.469	150
12	7/8	0.148	0.500	190	40	11⁄2	0.142	0.484	130
13	7/8	0.162	0.500	170	41	11/2	0.148	0.500	120
14	1	0.106	0.281	380	42	11/2	0.162	0.500	110
15	1	0.106	0.375	360	43	13⁄4	0.106	0.375	220
16	1	0.120	0.438	270	44	13⁄4	0.120	0.438	160
17	1	0.120	0.500	220	45	13⁄4	0.120	0.500	140
18	1	0.135	0.469	210	46	13⁄4	0.135	0.469	130
19	1	0.142	0.484	190	47	13⁄4	0.142	0.484	120
20	1	0.148	0.500	170	48	13⁄4	0.148	0.500	110
21	1	0.162	0.500	150	49	13⁄4	0.162	0.500	92
22	11⁄в	0.106	0.375	320	50	3/4	0.120	0.375	290
23	11⁄8	0.120	0.438	240	51	7/8	0.120	0.375	259
24	11⁄8	0.135	0.469	190	52	1	0.120	0.375	232
25	11⁄8	0.142	0.484	170	53	11⁄4	0.120	0.375	209
26	1 1⁄8	0.148	0.500	160	54	11⁄2	0.120	0.375	179
27	11⁄8	0.162	0.500	140	55	13⁄4	0.120	0.375	157
28	11/4	0.106	0.375	300					



TABLE 30 Type I, Style 20—Roofing Nails^A

Note-Copper-clad wire, flat head, diamond point, round smooth shank.




					F 1667	NLRFC				· · · · · · · · · · · · · · · · · · ·	
Dash No.	S	L	D	н	No./lb	Dash No.	S	L	D	н	No./Ib
01	2d	1	0.120	0.375	280	04	5d	13/4	0.120	0.375	160
02	3d	11/4	0.120	0.375	220	05	6d	2	0.120	0.375	140
03	4d	11/2	0.120	0.375	190	06	7d	21/4	0.120	0.375	130

All dimensions are given in inches.

TABLE 31 Type I, Style 20-Roofing Nails^A

NOTE-Steel wire, leak-resistant convex head, diamond point, round smooth shank, zinc coated.

13/4



0.135

0.135

0.500

0.500

110

98

02 2


All dimensions are given in inches.

01

🕼 F 1667

TABLE 32 Type I, Style 20—Roofing Nails^A

Note-Steel wire, flat reinforced head, needle or diamond point, round smooth shank, bright or zinc coated, as specified. (For prepared felt roofing.)





		ASTM ide	ntifier						
					a Alexandra and a second and a s				
				F 1667	NLRFR				
•	L	D	н	No./Ib	Dash No.	L	D	н	No./Ib
	3/4	0.106	0.625	190	06	1	0.120	0.625	150
	3/4	0.120	0.625	170	07	11/8	0.106	0.625	170
	7/8	0.106	0.625	180	08	11/8	0.120	0.625	140
	7/8	0.120	0.625	160	09	11/4	0.106	0.625	160
	1	0.106	0.625	170	10	11/4	0.106	0.625	140

^A All dimensions are given in inches.

TABLE 33 Type I, Style 20-Roofing Nails^A

Note-Steel wire, 1-in. flat integral steel cap, diamond point, round mechanically deformed shank, bright finish for roofing felts.





- Identifies a reinforced

Z = zinc coated

head roofing nail with a length of 1, a diameter of 0.106, and a head diameter of 0.625, and a bright finish. B = bright


			F 1667	NLRFD			
Dash No.	L	D	No./Ib	Dash No.	L	D	No./Ib
01	1/2	0.106	130	07	11/4	106	100
02	5/8	0.106	120	08	11/2	106-120	96-84
03	3/4	0.106	115	09	13/4	106-120	94-85
04	7/8	0.106	110	10	2	106-120	90-74
05	1	0.106	110	11	21/2	106-120	80-61
06	11⁄8	0.106	110	12	3	106	70

^A All dimensions are given in inches.

∰ F 1667

TABLE 34 Type I, Style 20—Roofing Nails^A

Note—Aluminum alloy wire, flat head with neoprene washer (for aluminum roofing sheet), diamond point, round, smooth, or mechanically deformed shank, as specified.




		F 1667 NLRFNS	6		F 1667 NLRFND				
Dash No.	L	D	н	No./lb	Dash No.	L	D	н	No./lb
01	13/4	0.135	0.438	320	01	13/4	0.145	0.438	290
02	2	0.135	0.438	280	02	2	0.145	0.438	260
03	21/4	0.135	0.438	240	03	21/4	0.145	0.438	230
04	21/2	0.135	0.438	210	04	21/2	0.145	0.438	210

A All dimensions are given in inches.

TABLE 35 Type I, Style 21—Shingle Nails^A

Note-Aluminum Alloy wire, flat head, diamond point, round, smooth or mechanically deformed shank, as specified.




		F 1667 NLSHAD)				F 1667 NLSHAS		
Dash No.	L	D	н	No./lb	Dash No.	L	D	Н	No./Ib
01	11/4	0.101	0.191	1060	01	7/8	0.099	0.281	1310
02	11/2	0.101	0.191	860	02	11/4	0.080	0.219	1480
03	13/4	0.105	0.191	720	03	11/4	0.099	0.281	1010
04	2	0.105	0.191	610	04	11/4	0.113	0.312	780
05	21/4	0.113	0.200	180	05	11/2	0.113	0.312	660
06	21/2	0.113	0.200	130	06	13/4	0.113	0.312	610

🖽 F 1667

TABLE 36 Type I, Style 21-Shingle Nails^A

Note-Steel wire, flat head, diamond point, round, smooth (standard) or barbed (for special shingles) shank, bright or zinc coated, as specified.



^A All dimensions are given in inches.

3.5d

4d

13/8

11/2

02

03

TABLE 37 Type I, Style 22—Siding Nails^A

310

260

. .

0.099

0.106

0.281

0.281

11/2

13/4

2

03

04

0.113

0.113

0.113

0.406

0.406


0.406

210

180

162

Note-Aluminum alloy wire, flat head (insulated), casing or countersunk head (wood), as specified, diamond point, round smooth shank or, when specified, square-barbed shank.




		Flat Head =			= Countersunk Head						
		[<u> </u>	>	-						
					F 1667	7 NLSDF					· · · · · · · · · · · · · · · · · · ·
Da	ish No.		L			D		н		No./lb	, <u> </u>
	01 02 03 04		11⁄2 11⁄2 2 21⁄2		0. 0.	113 113 113 135		0.219 0.312 0.219 0.219			
		F 1667	NLSDC			F 1667 NLSDK					
Dash No.	S	L	D	н	No./lb	Dash No.	S	L	D	н	No./Ib
01	6d	17/8	0.106	0.141	600	01	6d	17⁄8	0.106	0.266	600
02	7d	21/8	0.113	0.141	470	02	7d	21/8	0.113	0.266	470
03	8d	23/8	0.128	0.156	320	03	8d	2³/s	0.128	0.297	320
04	9d	25/a	0.148	0.189	200	04	9d	25/a	0.148	0.312	200

∰ F 1667

TABLE 38 Type I, Style 23—Slating Nails^A

Note—Aluminum alloy, copper or steel wire as specified. Aluminum and copper nails shall have a flat head (0.312 to 0.375–in. diameter), diamond point, and round smooth shank or, when specified, square-barbed shank. Steel nails shall have a flat, slightly countersunk head, diamond point, round smooth shank, zinc coated.



Steel =

= Aluminum or Copper


73

		F 1667	' NLSLA		
Dash No.		L	D		No./Ib
01		7/8	0.106		1170
02		1	0.106		1150
03		11/4	0.106		670
04		11/4	0.120	620	
05		11/4	0.135		520
06 11/2		0.120		530	
07 11/2		0.135		430	
		F 1667	NLSLC		
01		1	0.109	<u> </u>	290
02 11/4		11/4	0.109		240
03 11/4		0.120		210	
04		11/4	0.135		160
05		11/2	0.109		200
06		11/2	0.120		160
07		11/2	0.135		130
08		13/4	0.135		120
09		2	0.135		110
F 166		V NLSLS		<u> </u>	
Dash No.	S	L	D	H	No./Ib
01	2d	1	0.106	0.312	420
02	3d 11/4		0.128 0.375		220
03	4d	11/2	0.128 0.375		190
04	5d	13/4	0.135	0.406	140
05	6d	2	0.148	0.438	100

🕼 F 1667

TABLE 39 Type I, Style 24—Rubber Heel Nails^A


Note-Steel wire, flat or countersunk head, as specified, needle point, round smooth shank, bright finish.



All dimensions are given in inches.

TABLE 40 Type I, Style 25-Underlayment Nails^A

Note-Steel wire, flat or flat, slightly countersunk head, diamond point, round, mechanically deformed shank, bright finish.




Dash No.	L	D	н	No./Ib	Dash No.	L	D	Н	S	No./lb
01	1	0.080	0.188		07	11/2	0.099	0.250		330
02	11/4	0.080	0.188	600	08	15⁄8	0.099	0.250		300
03	11/4	0.099	0.250	400	09	13/4	0.099	0.250		280
04	13/8	0.080	0.188	540	10	17/a	0.106	0.266	6d	170
05	13/8	0.099	0.250	360	11	21/8	0.109	0.266	7d	170
06	11/2	0.080	0.188	500	12	23/8	0.113	0.297	8d	140

∰ F 1667

TABLE 41 Type I, Style 26—Barbed Nails^A

NOTE-Steel wire, flat head, diamond point, square barbed shank, bright finish.




Dash No.	S	Style	L	Diagonal	Square Dimension	н	No./Ib
01	6d	common	2	0.113	0.080 × 0.102	0.250	200
02	8d	common	21/2	0.131	0.092×0.120	0.266	120
03	10d	common	3	0.148	0.105 × 0.135	0.281	84
04	16d	common	31/2	0.162	0.113 × 0.149	0.312	59
05	20d	common	4	0.192	0.135 × 0.170	0.375	39
06	6d	box	2	0.099	0.072×0.089	0.250	260
07	8d	box	21/2	0.113	0.080×0.102	0.266	150
08	6d	finish	2	0.092	0.062×0.083	0.124	320
09	8d	finish	21/2	0.099	0.072×0.089	0.131	230
10		truss	11/2	0.131	0.092×0.120	0.281	190

^A All dimensions are given in inches.

TABLE 42 Type I, Style 27—Masonry Drive Nails^A

Note—Hardened steel, flat head, cone pilot point, round, high pitch, multiple-start threaded shank, bright finish. When specified, masonry drive nails shall be proof lead tested.




Dash No.	S	L	Thread Diameter	Dash No.	S	L	Thread Diameter
01	3/32	3/4	0.125	4	3/18	11/4	0.215
02	1/8	3/4	0.156	5	1/4	11/2	0.258
03	5/32	1	0.188	6	5/18	2	0.330

∰ F 1667

TABLE 43 Type I, Style 28—Escutcheon Nails^A

NOTE-Steel or brass wire, as specified, oval head, diamond point, round smooth shank.



Dash No.	L	D	Dash No.	L	D	Dash No.	L	D
01	1/4	0.035	14	3/4	0.072	27	2	0.080
02	1/4	0.048	15	3/4	0.080	28	2	0.092
03	1/4	0.062	16	3/4	0.092			
04	1/4	0.072	17	1	0.048			
05	1/4	0.080	18	1	0.062			
06	1/2	0.035	19	1	0.072			
07	1/2	0.048	20	1	0.080			
08	1/2	0.062	21	1	0.092			
09	1/2	0.072	22	11⁄4	0.062			
10	1/2	0.080	23	11⁄4	0.080			
11	1/2	0.092	24	11/4	0.092			
12	3/4	0.048	25	1 1/2	0.080			
13	3/4	0.062	26	11/2	0.092			

All dimensions are given in inches.

TABLE 44 Type I, Style 29-Glulam Rivet^A

No./Ib


59

34

24

Note-Hardened steel, flat countersunk head, diamond point, smooth shank, zinc coated, as specified.

0.250



^A All dimensions are given in inches.

03

^B Tolerances: $D_w - \pm 0.010$, $D_t - \pm 0.005$, $H_w - \pm 0.010$, and $H_t - \pm 0.010$.

31/2

0.125


0.345

0.220

∰ F 1667

TABLE 45 Type II, Style 1—Common Cut Nails^A

NOTE-Steel or copper, flat head, bright finish.




Dash No.	S	L	Dash No.	S	L	Dash No.	S	L
01	2d	1	07	7d	21/4	13	20d	4
02	3d	11/4	08	8d	21/2	14	30d	41/2
03	31/2d	13/8	09	9d	23/4	15	40d	5
04	4d	11/2	10	10d	3	16	50d	51/2
05	5d	13/4	11	12d	31/4	17	60d	6
06	6d	2	12	16d	31/2			

All dimensions are given in inches.




Note-Steel, flat head, bright finish.



∰ F 1667

TABLE 47 Type II, Style 3—Clout Cut Nails^A

NOTE—Steel, flat head, bright finish, blued or zinc coated, as specified (see 5).



All dimensions are given in inches.

TABLE 48 Type II, Style 4—Common Cut Nails^A

0.083

0.2715

No./lb

670


610

450

350

NOTE-Steel, oval head, bright finish, blued, brass or copper plated, as specified.

11/4




^A All dimensions are given in inches.

04

∰ F 1667

TABLE 49 Type II, Style 5—Cobblers Cut Nails^A

NOTE—Steel casing head, clinch point, bright finish or brass plated, as specified.




Dash No.	L	Т	н	No./lb
01	1/2	0.065	0.109	1950
02	5/8	0.065	0.109	1500
03	3/4	0.065	0.109	1340

~ 7

A All dimensions are given in inches.

TABLE 50 Type II, Style 6-Extra-Iron Clinching Cut Nails^A

NOTE-Steel, casing head, clinch point, bright finish or blued, as specified.




Dash No.	L	т	н	No./Ib	Dash No.	L	Ţ	н	No./lb
01	3/8	0.049	0.093	4.130	06	11/18	0.049	0.093	2000
02	7/16	0.049	0.093	3.400	07	3/4	0.0535	0.101	1640
03	1/2	0.049	0.093	3.040	08	13/18	0.0535	0.101	1600
04	9/16	0.049	0.093	2.864	09	7/8	0.0535	0.101	1520
05	5/8	0.049	0.093	2.260					

🕼 F 1667

TABLE 51 Type II, Style 7—Hob Cut Nails^A


NOTE-Steel, square grooved head, clinch point, bright finish, or blued, as specified.



A All dimensions are given in inches.

TABLE 52 Type III, Style 1—Common Spikes^A


Note—These spikes shall be sheared from medium carbon sheet steel and shall have a wedged-shaped shank with a square point end narrower than the upset head end. They shall have a flat head, bright finish, or zinc coated, as specified.



∰ F 1667

TABLE 53 Type III, Style 2—Gutter Spikes^A

Note-Steel wire, oval head, chisel point, flat head, diamond point, bright finish or zinc coated, as specified.




() <u> </u>			\blacktriangleright
	F 1667	SPGTF	
Dash No.	L	D	Н
01	61/2	0.250	0.562
02	7	0.250	0.562
03	8	0.250	0.562
04	81/2	0.250	0.562
05	9	0.250	0.562
06	10	0.250	0.562
07	101/2	0.250	0.562
	F 1667	SPGTO	
Dash No.	L	D	Н
01	61/2	0.250	0.531
02	7	0.250	0.531
03	8	0.250	0.531
04	81/2	0.250	0.531
05	9	0.250	0.531
06	10	0.250	0.531
07	101/2	0.250	0.531

^A All dimensions are given in inches.

∰ F 1667

TABLE 54 Type III, Style 3—Round Spikes^A

Note-Steel wire, oval countersunk head, chisel point, flat head, diamond point, bright finish or zinc coated, as specified.



-Identifies a round spike with an oval head, a length of 5, a shank diameter of 0.2625, a head diameter of 0.531, and a bright finish. C = oval countersunk headF = flat headB = brightZ = zinc coated







= Flat Head


		F 1667 SPRD	C ^A		F 166	7 SPRDF ^A		
Dash No.	S	L	D	Н	Dash No.	L	D	Н
01	40d	5	0.2625	0.531	01	8	0.312	0.625
02	50d	51/2	0.283	0.562	02	8	0.312	0.750
03	60d	6	0.283	0.562	03	9	0.312	0.750
04		7	0.312	0.625	04	10	0.312	0.750
					05	8	0.375	0.750

^AAll dimensions are given in inches.

∰ F 1667

TABLE 55 Type III, Style 4—Barge and Boat Spikes^A


Note-Wrought iron, hot rolled steel rod or steel wire, square, diamond or oval head, chisel point, bright finish or zinc coated, as specified.



	F 1667 SPBB						
Dash No.	D-Square	Н	L	Dash No.	D-Square	н	L
01	1/4	17/32	3	26	7/16	13/16	8
02	1/4	17/32	31/2	27	7/16	13/16	9
03	1/4	17/32	4	28	7/16	13/18	10
04	1/4	17/32	5	29	7/18	13/16	11
05	1/4	17/32	6	30	7/18	13/18	12
06	1/4	17/32	7	31	1/2	1	6
07	1/4	17/32	8	32	1/2	1	7
08	5/16	19/32	31/2	33	1/2	1	8
09	5/16	19/32	4	34	1/2	1	9
10	5/16	19/32	5	35	1/2	1	10
11	⁵ /16	19/32	6	36	1/2	1	11
12	5/16	19/32	7	37	1/2	1	12
13	5/16	19/32	8	38	5/8	11⁄8	8
14	3/8	11/18	3	39	5/8	11/6	9
15	3/6	11/18	31/2	40	5/8	11/8	10
16	3/8	11/18	4	41	5/8	11⁄a	11
17	3/8	11/16	5	42	5/8	11/8	12
18	3/8	11/16	6				
19	3/8	11/16	7				
20	3/8	11/16	8				
21	3/8	11/16	9				
22	3/8	11/16	10				
23	3/8	11/18	11				
24	7/18	13/16	6				
25	7/16	13/16	7				

🕼 F 1667


TABLE 56 Type IV, Style 1—Fence Staples^A



^A All dimensions are given in inches.

TABLE 57 Type IV, Style 2—Poultry Netting Staples^A


Note-Steel wire, zinc coated.



∰ F 1667

TABLE 58 Type IV, Style 3—Flat Top Crown Staples^A

Note—Steel wire, aluminum alloy wire, bright finish, zinc coated, cement coated or chemically etched, as specified. (For use in power tools for fastening wood and other materials to wood.)



	F 1667 STFC						
Dash No.	С	G ^B	L	Dash No.	С	G ^B	L
01	3/16	18	3/8	51	7/16	14	11/2
02	3/18	18	1/2	52	7/16	14	15⁄a
03	3/16	18	5/8	53	7/18	14	13/4
04	3/16	18	3/4	54	7/18	14	17/8
05	3/16	18	7/8	55	7/16	14	2
06	3/18	18	1	56	7/18	14	21/4
07	3/16	18	11/8	57	7/16	14	21/2
08	3/16	18	11/4	58	7/16	15	3/8
09	3/8	14	3/8	59	7/18	15	1/2
10	3/8	14	1/2	60	7/16	15	5/8
11	3/8	14	5/8	61	7/18	15	3/4
12	3/8	14	3/4	62	7/16	15	7/8
13	3/6	14	7/8	63	7/16	15	1
14	3/8	14	11/8	64	7/16	15	11⁄a
15	3/8	14	11/4	65	7/16	15	11/4
16	3/8	14	13/8	66	7/16	15	13/8
17	3/6	14	11/2	67	7/16	15	11/2
18	3/8	14	15/8	68	7/16	15	15/a
19	3/8	14	15/6	69	7/16	15	13/4
20	3/8	16	13/4	70	7/16	15	17/a
21	3/8	16	1/2	71	7/16	15	2
22	3/6	16	5/8	72	7/16	15	21/4
23	3/8	16	3/4	73	7/16	15	21/2
24	3/8	16	7/8	74	7/16	16	2 72 3/8
25	-78 3/8	16	11/8	75	7/16	16	1/2
26	-98 3∕8	16	11/4	76	7/16	16	5/8
20	3/8	16	13/8	77	7/16	16	3/4
28	-78 3/8	16	11/2	78	7/16	16	7/8
28	3/8 3/8		15/B	78	7/16		-78 1
30	-76 3/8	16 16	13/4	80	7/16 7/16	16 16	11⁄a
30				81			
	3/8	18	3/8		7/16	16	11/4
32	3/8	18	1/2	82	7/16	16	13⁄8
33	3/8	18	5/B	83	7/16	16	11/2
34	3/8	18	3/4	84	7/16	16	15/8
35	3/8	18	7/8	85	7/16	16	13/4
36	3/8	18	11/8	86	7/16	16	17/8
37	3/8	18	11/4	87	7/16	16	2
38	3/8	18	11/4	88	7/16	16	21/4
39	3/8	18	11/2	89	7/16	16	21/2
40	3/8	18	15/8	90	1/2	14	1/2
41	3/B	18	13/4	91	1/2	14	5/8
42	7/16	14	3/8	92	1/2	14	3/4
43	7/16	14	1/2	93	1/2	14	7/8
44	7/16	14	5/8	94	1/2	14	1
45	7/16	14	3/4	95	1/2	14	11⁄8
46	7/18	14	7/8	96	1/2	14	11/4
47	7/18	14	1	97	1/2	14	13⁄a
48	7/16	14	11/8	98	1/2	14	11/2
49	7/16	14	11/4	99	1/2	14	16/a
50	7/16	14	13/8	100	1/2	14	13/4

🕼 F 1667

			F 100/	7 STFC			
Dash No.	С	G ^ø	L	Dash No.	С	G#	L
101	1/2	14	17/0	164	7/6	14	7/8
102	1/2	14	2	165	7/8	14	1
103	1/2	14	21/4	166	7/8	14	11/8
104	1/2	14	21/2	167	7/8	14	11/4
105	1/2	15	1/2	168	7/6	14	13/8
106	1/2	15	%	169	7/8	14	11/2
107	1/2	15	¥4	170	7/8	14	1%
108	1/2	15	7/8	171	7/8	14	13/4
109	1/2	15	1	172	7/8	14	17/8
110	1/2	15	11/8	173	7/8	14	2
111	1/2	15	11/4	174	7/8	16	1/2
112	1/2	15	1%	175	7/8	16	5/6
113	1/2	15	11/2	176	7/8	16	₹⁄4
114	1/2	15	15/8	177	7/8	16	7/8
115	1/2	15	1%	178	7/8	16	1
116	1/2	15	17/8	179	7/8	16	11/0
117	1/2	15	2	180	7/8	16	11/4
118	1/2	15	21/4	181	7/8	16	13/8
119	1/2	15	21/2	182	7/8	16	11/2
120	1/2	16	1/2	183	7/6	16	1%
121	1/2	16	5/8	184	7/8	16	13/4
122	1/2	16	\$4	185	7/8	16	17/8
123	1/2	16	7/8	186	7/8	16	2
124	1/2	16	1	187	16/10	14	1/2
125	1/2	16	11/8	188	15/10	14	5/8
126	1/2	16	11/4	189	18/16	14	3/4
127	1/2	16	1%	190	16/18	14	7/8
128	1/2	16	11/2	191	16/10	14	1
129	1/2	16	15/8	192	16/16	14	11/8
130	1/2	16	13/4	193	16/18	14	11/4
131	1/2	16	17/8	194	16/18	14	1%
132	1/2	16	2	195	16/18	14	11/2
133	1/2	16	21/4	196	15/18	16	1/2
134	1/2	16	21/2	197	15/18	16	5/8
135	4	14	1/2	198	16/16	16	3/4
136	3/4	14	5/a	199	15/16	16	7/8
137	3/4	14	3/4	200	18/16	16	1
138	3/4	14	7/8	201	15/18	16	11/8
139	3/4	14	1	202	15/16	16	11/4
140	3/4	14	11/8	203	15/16	16	13/0
141	3/4	14	11/4	204	16/16	16	11/2
142	3/4	14	1%	205	1	14	1/2
143	3/4	14	11/2	206	1	14	5/0
144	3/4	14	15/8	207	1	14	3/4
145	3/4	14	13/4	208	1	14	7/8
146	3/4	14	17/8	209	1	14	1
147	¥4	14	2	210	1	14	11/8
148	3/4	16	1/2	211	1	14	11/4
149	3/4	16	6/s	212	1	14	13/8
150	3/4		3/4	213	1	14	11/2
151	3/4	16 16	7/8	214	1	16	1/2
152	3/4	16	1	215	1	16	5/s
153	44 44	16	11/1	216	1	16	78 \$⁄4
154	44 44	16	11/4	217		16	7/8
155	3/4	16	1%	217	1	16	″∎ 1
155	44 3/4	16	11/2	218	1	16	11/8
156	*4 *4	16	1 1/2 15/8	219	1	16	1 78
107	74	16	19⁄8 13⁄4	220	1	10	11/4
158	3/4		19/4 17/8	221	1	16	1% 11/
159	3/4 3/4	16 16		222	1	16	11/2
160	3/4	10	2	223	1% 1 ¹⁷ / ₃₂	12	¥4 3/4
161 162	7/8 7/8	14 14	1/2 5/8	224 225	11//32 21/6	12 10	¥4 1

A All dimensions are given in inches.

^B Dimensions and tolerances for gages of flat top crown staples:


18 Gage (0.0475) $\left[0.0435 \frac{+0.0040}{-0.0060} T \right] \times \left[0.0475 \frac{+0.0060}{-0.0020} W \right]$
16 Gage (0.0625) $\left[0.0570 \frac{+0.0055}{-0.011} T \right] \times \left[0.0625 \frac{+0.0075}{-0.0025} W \right]$
15 Gage (0.0720) $\left[0.0690 \frac{+0.0030}{-0.0086} T \right] \times \left[0.0720 \frac{+0.0086}{-0.0030} W \right]$

14 Gage (0.0800) $\left[0.0775 \frac{+0.0025}{-0.0096} T \right] \times \left[0.0800 \frac{+0.0096}{-0.0025} W \right]$ 12 Gage (0.1055) $\left[0.1015 \frac{+0.0040}{-0.0126} T \right] \times \left[0.1055 \frac{+0.0126}{-0.0040} W \right]$ 10 Gage (0.1350) $\left[0.1300 \frac{+0.0050}{-0.0162} T \right] \times \left[0.1350 \frac{+0.0162}{-0.0050} W \right]$

∰ F 1667

TABLE 59 Type IV, Style 3—Flat Top Crown Staples^A

Note—Steel wire, chisel point, tin plated, zinc coated or lacquer finish, as specified, cohered together in strips. (For use in staple tackers or machines.) The number per strip shall be as specified and shall be suitable for use in the make and model of tool specified.




	F 1667 STFCC							
Dash No.	L	T × W	Св	Dash No.	L	T × W	CB	
01	3/18	0.020 × 0.030	0.500	10	9/18	0.020 × 0.050	0.437	
02	1/4	0.020×0.030	0.500	11	3/8	0.030×0.050	0.164	
03	5/16	0.020×0.030	0.500	12	1/2	0.030×0.050	0.164	
04	1/4	0.020×0.050	0.500	13	5/8	0.030×0.050	0.164	
05	5/18	0.020×0.050	0.500	14	3/4	0.030×0.050	0.164	
06	3/8	0.020×0.050	0.500	15	7/8	0.030×0.050	0.164	
07	1/2	0.020×0.050	0.500	16	1	0.030×0.050	0.164	
08	3/8	0.020×0.050	0.437	17	11⁄8	0.030×0.050	0.164	
09	1/2	0.020×0.050	0.437	18	11/4	0.030×0.050	0.164	

All dimensions are given in inches.

^B Crown width, C, tolerances: 0.500 ± 0.015 , 0.437 ± 0.010 , and 0.164 ± 0.015 .

TABLE 60 Type IV, Style 4—Round or "V" Crown Staple A

Note—Steel wire or copper-clad wire, bright finish, zinc coated, cement coated or chemically etched, as specified. (For use in power tools for fastening wood and other materials to wood.)



10

11

12

0.435

0.435

0.435

G

16

16

16

16

16

16

L

1/2

9/16

5/8

3/4

7/8

1

A All dimensions are given in inches.

Dash No.

01

02

03

04

05

06

^B Crown width tolerances: +0.015 and -0.000.

СВ

0.346

0.346

0.346

0.346

0.346

0.346

16

16

16

3/4


7/a

1

∰ F 1667

TABLE 61 Type IV, Style 5—Preformed Staples^A


NOTE-Steel wire, chisel point, zinc or cement coated, as specified. Copper-clad wire, chisel point, tinned or other plated finish, as specified. (Hand driven.)



A All dimensions are given in inches.


TABLE 62 Type IV, Style 6—Electrical Staples^A


Note-Insulated or uninsulated, as specified.



Dash No.	L	С	D	Flatten	Point Length	Point Angle	No./Ib
01	3/8	5/32	0.067	0.048	1/4	12	1440
02	1/2	3/18	0.072	0.057	1/4	12	990
03	5/8	1/4	0.072	0.057	5/16	12	740
04	3/4	3/18	0.083	0.060	11/32	12	480
05	3/4	1/4	0.083	0.060	11/32	12	450
06	7/8	1/4	0.083	0.060	11/32	12	400
07	7/8	7/18	0.083	0.060	11/32	12	370
08	1	1/2	0.120	0.050 × 0.215	3/8	18	
09	11/4	5/8	0.120	0.050×0.215	3/8	18	

∰ F 1667





 Identifies a preformed hoop staple with a length of 1/2, a width of 1/2, and a diameter of 0.072.

Dash No.	L	С	D	Flatten	No./lb
01	1/2	1/2	0.072	0.057	720
02	1/2	1/2	0.083	0.060	470
03	5/8	1/2	0.072	0.057	580
04	5/8	1/2	0.083	0.060	430
05	3/4	1/2	0.072	0.057	490
06	3/4	1/2	0.083	0.060	370
07	1/2	5/8	0.072	0.057	670
08	1/2	-78 5/8	0.083	0.060	470
09	5/8	5/8	0.072	0.057	530
			0.083	0.060	400
10	5/8	5/8		0.057	400 460
11	3/4	5/8	0.072		
12	3/4	5/8	0.083	0.060	340
13	1/2	3/4	0.072	0.057	580
14	1/2	3/4	0.083	0.060	430
15	1/2	3/4	0.109	0.083	260
16	5/8	3/4	0.072	0.057	490
17	5/8	3/4	0.083	0.060	370
18	5/8	3/4	0.109	0.083	220
19	3/4	3/4	0.072	0.057	430
20	3/4	3/4	0.083	0.060	320
21	3/4	3/4	0.109	0.083	190
22	1	3/4	0.072	0.057	350
23	1	3/4	0.083	0.060	260
24	1	3/4	0.109	0.083	150
25	1/2	7/8	0.072	0.057	530
26	1/2	7/8	0.083	0.060	400
27	5/8	7/8	0.072	0.057	460
28	5/8	7/8	0.083	0.060	340
29	3/4	7/8	0.072	0.057	410
30	3/4	7/8	0.083	0.060	300
31	7/8	7/8	0.072		360
32	7/8 7/8	*/8 7/8	0.083	0.057 0.060	270
		'/e 1			
33	5/8	•	0.083	0.060	320
34	5/8	1	0.109	0.083	200
35	3/4	1	0.083	0.060	290
36	3/4	1	0.109	0.083	180
37	7/8	1	0.083	0.060	260
38	7/8	1	0.109	0.083	160
39	1	1	0.083	0.060	240
40	1	1	0.109	0.083	140
41	3/4	11/4	0.083	0.060	220
42	3/4	11/4	0.109	0.083	130
43		11/4	0.083	0.060	180
44	1	11/4	0.109	0.083	140

A All dimensions are given in inches.

SUPPLEMENTARY REQUIREMENTS

The following supplementary requirements shall apply only when specified in the order or contract (5.1.7). Details of these supplementary requirements shall be agreed upon in writing between the manufacturer and the purchaser.

S1. Nail Bending Yield Strength

S1.1 When specified as a supplementary requirement for

nails used for engineered construction, the nail's average bending yield strengths shall meet, as a minimum, the yield strengths used in determining the lateral design loads tabulated in the AF&PA National Design Specification⁶ for Wood Construction, NDS,⁶ Part XII: Nails and Spikes.

S1.2 The minimum average bending yield strengths used by the NDS⁶ as a function of the material and diameter of the nail are given in Table S1.1 and Table S1.2.

S1.3 *Test Method for Yield Strength*—In order to conform with the supplementary requirements of S1, the procedure of Test Method F 1575 shall be conducted on nail samples.

S1.4 At least five nails from each lot of 100 individual containers shall be examined and tested to determine conformance with this supplementary requirement.

S1.5 When labeled "Engineered Construction Nails, ASTM F 1667," nails must meet all requirements of F 1667 including Supplementary Requirements.

TABLE S1.1 Low to Medium Carbon Steel Nails and Spikes

Nominal Diameter, in.	Bending Yield, psi
0.099 ≤ 0.142	100 000
>0.142 ≤ 0.177	90 000
>0.177 ≤ 0.254	80 000
>0.254 ≤ 0.273	70 000
>0.273 ≤ 0.344	60 000
>0.344 ≤ 0.375	45 000

TABLE S1.2 Medium Carbon Steel Nails—Hardened

Nominal Diameter, in.	Bending Yield, psi
$0.120 \le 0.142$	130 000
>0.142 ≤ 0.192	115 000
>0.192 ≤ 0.207	100 000

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).

[🕼] F 1667

⁶ Available from American Forest and Paper Association (AF&PA), 1111 19th Street, NW, Suite 800, Washington, DC 20036, *National Design Specification*[®], (*NDS*[®]), for Wood Construction.