



Standard Practice for Application of Hose Stream¹

This standard is issued under the fixed designation E 2226; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last approval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

Several fire-test-response standards (such as ASTM E 119, E 814, E 2074, and E 1966) in order to assess the integrity of building elements after exposure to a specified test fire, require test specimens to be evaluated by exposure to a hose stream. It is important to standardize certain elements of the hose stream to promote uniformity in requirements. To attain this goal, this practice describes a standard apparatus for delivering a solid stream of water and prescribes a standard method of subjecting building elements to a hose stream after fire exposure.

1. Scope

1.1 This practice is applicable to building elements required to be subjected to the impact, erosion, and cooling effects of a hose stream as part of a fire-test-response standard. Building elements include, but are not limited to, wall and partition assemblies, fire-resistive joint systems, and doors.

1.2 This practice shall register performance of the building element under specific hose stream conditions. It shall not imply that, either after exposure or under other conditions, the structural capability of the building element is intact or that the building element is suitable for use.

1.3 The result derived from this practice is one factor in assessing the integrity of building elements after fire exposure. The practice prescribes a standard hose stream exposure for comparing performance of building elements after fire exposure and evaluates various materials and construction techniques under common conditions.

1.4 *Units*—The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the practice. Within the text, the SI units are shown in brackets.

1.5 The text of this standard references notes which provide explanatory material. These notes shall not be considered as requirements of the standard.

1.6 This standard is used to measure and describe the response of materials, products, or assemblies to heat and flame under controlled conditions, but does not by itself incorporate

all factors required for fire risk assessment of the materials, products, or assemblies under actual fire conditions.

1.7 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

E 119 Test Methods for Fire Tests of Building Construction and Materials²

E 176 Terminology of Fire Standards²

E 631 Terminology of Building Constructions³

E 814 Test Method of Fire Tests of Through-Penetration Fire Stops²

E 1966 Test Method for Fire-Resistive Joint Systems²

E 2074 Methods of Fire Tests of Door Assemblies²

2.2 UL Standard:

UL 385 Standard for Safety Play Pipes for Water Supply Testing in Fire-Protection Service⁴

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice, refer to Terminologies E 176 and E 631.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *building element, n*—a component or assembly of materials using products manufactured as independent units capable of being joined with or placed within other components or assemblies to create a structure.

¹ This practice is under the jurisdiction of ASTM Committee E05 on Fire Standards and is the direct responsibility of Subcommittee E05.11 on Fire Endurance.

Current edition approved Aug. 10, 2002. Published November 2002.

² *Annual Book of ASTM Standards*, Vol 04.07.

³ *Annual Book of ASTM Standards*, Vol 04.11.

⁴ Available from Underwriters Laboratories (UL), Corporate Progress, 333 Pfingsten Rd., Northbrook, IL 60062.

3.2.2 *exposed area, n*—the total surface area of the test assembly that is subjected to the fire endurance test including, when required, the supporting construction.

3.2.3 *fully developed stream, n*—a coherent, forceful projection of water similar in shape and intensity to the stream being applied to the exposed side of the test assembly from the nozzle.

3.2.4 *supporting construction, n*—construction required for the testing of some building elements into which the test specimen is assembled, for example, the wall into which a door is fitted.

3.2.5 *test assembly, n*—the building element or elements being tested and, if applicable, the supporting construction.

4. Significance and Use

4.1 This practice is intended to standardize the apparatus used and the method or pattern of application of a standard hose stream to building elements as one part of the assessment and fire resistance classification of building elements.

4.2 This practice is intended to be used only after a test assembly has completed a prescribed standard fire endurance test.

4.3 The practice exposes a test assembly to a standard hose stream under controlled laboratory conditions.

4.3.1 Water pressure and duration of exposure are not specified in this practice. Duration of exposure, water pressure, and pass/fail criteria are defined in the appropriate fire test method.

4.3.2 This exposure is not intended to replicate typical fire fighting operations or all applied or impact loads a system could be subjected to in field use and conditions.

4.4 Any variation from tested conditions has the potential of substantially changing the performance characteristics determined by this practice.


5. Apparatus

5.1 The apparatus used to apply the hose stream is shown in Fig. 1 and shall be capable of delivering a solid stream of water at the pressure specified in the fire endurance test method.

5.1.1 The water stream shall be delivered through a 2-1/2 in. (64 mm) hose discharging through a National Standard Playpipe of corresponding size equipped with a 1-1/8 in. (29 mm) discharge tip of standard taper, smooth-bore pattern without a shoulder at the orifice. Refer to UL 385.

5.1.2 The water pressure at the base of the nozzle shall be measured by providing a 12 in. (305 mm) length of a straight run 2-1/2 in. (64 mm) pipe between the hose and the playpipe. Eight inches downstream from one end, the pipe shall have an 1/8 in. (3.2 mm) diameter pressure tap drilled through the pipe sidewall with a pipe coupling welded or brazed concentrically over the hole. The pressure tap shall be flush with and perpendicular ($\pm 5^\circ$) to the inner wall of the pipe. Burrs or other irregularities shall be removed or corrected.

5.1.3 A pressure gauge calibrated in 1 psi (5 kPa) increments shall be fitted on the end of the coupling. The pressure gauge shall be capable of reading a maximum pressure of at



LEGEND

- 1. 1-1/8" (29 mm) discharge tip
- 2. 2-1/2" (64 mm) National Standard Playpipe
- 3. Adapter: 2-1/2" (64 mm) hose thread (male) to 2-1/2" (64 mm) NPT (female)
- 4. 2-1/2" (64 mm) standard schedule steel pipe nipple
- 5. Pipe coupling welded or brazed to the nipple, centered over a 1/8" (3.2 mm) hole in nipple
- 6. Pressure gauge
- 7. Adapter: 2-1/2" (64 mm) NPT (female) to 2-1/2" (64 mm) hose thread (female)
- 8. 2-1/2" (64 mm) standard fire hose

FIG. 1 Hose Stream Apparatus

least 59 psi (406 kPa) and shall have a full scale reading no greater than 300 psi (2070 kPa).

5.2 The hose stream apparatus shall be connected to a source of water capable of maintaining the required minimum pressure, as specified in the fire endurance test method, at the nozzle under flow conditions throughout the hose stream test.

6. Test Specimen and Conditioning

6.1 Prior to conducting the hose stream test, the test specimen shall be conditioned and fire tested as specified in the applicable fire endurance test method.

7. Nozzle Location

7.1 The nozzle tip shall be located so that its axis is 90° to the center of the test assembly as shown in Fig. 2. However, if the axis is other than 90°, refer to 7.2.1.

7.2 The distance between the center of the test assembly and the nozzle tip shall be 20 ± 1 ft (6.1 ± 0.3 m) as shown in Fig. 2.

7.2.1 The distance specified in 7.2 shall be decreased by 1 ft (305 mm) for each 10° deviation from the normal as shown in Fig. 3. The maximum deviation from the normal shall not exceed 30°.

8. Procedure

8.1 Prior to the fire test, the laboratory shall ensure that the discharge pressure specified in the fire endurance test method is capable of being attained.

8.2 Condition and fire test the test specimen in accordance with the requirements of the fire endurance test method.

8.3 Unless otherwise specified, immediately, but not longer than 10 min after the termination of the fire test, perform all of the following prior to the application of the hose stream:

8.3.1 Remove the test assembly and frame from the furnace, when applicable.

8.3.2 Position the test assembly in such a manner as to be able to apply the hose stream to the entire surface of the test assembly that had been exposed to the fire.

8.3.3 Position the tip of the nozzle at the specified distance from the center of the test assembly.

8.3.4 Adjust the nozzle hose stream to the specified pressure. During adjustment, the hose stream shall not contact the test assembly.

8.3.5 Videotape or photograph both the exposed and unexposed sides of the test assembly.

8.3.6 Position personnel to obtain an unobstructed view of both the exposed and unexposed sides of the test assembly during the hose stream test.

8.3.7 Commence the application of the hose stream as described in 8.4.

8.4 Commence the hose stream test by directing the hose stream to one corner of the test assembly first. Continue to direct the stream to the entire exposed face of the test assembly in accordance with the following:

8.4.1 Pass the hose stream across the test assembly at a rate of 3 to 6 feet per second (0.9 to 1.8 metres per second). Movement from one side of the test assembly to the other constitutes one pass.

8.4.2 When changing directions to make the return pass, change direction slowly and off of the test assembly without




FIG. 2 Nozzle Tip Position Relative to Exposure Face of Test Specimen




FIG. 3 Nozzle Tip Position Correction for Deviation from 90°

halting the directional movement of the application of the hose stream. Moving the nozzle from side to side, apply the hose stream to cover the entire exposed face of the fire test assembly. After completing the side-to-side application of the hose stream, immediately change direction and apply the hose stream over the exposed face of the assembly by moving the nozzle at right angles to the side-to-side application. Fig. 4 is one example of the pattern that shall be used.

NOTE 1—Ideally, the difference between the number of hose stream passes in the horizontal direction compared to the vertical direction does not exceed 10 % of the total.

8.4.3 As defined in the fire-test-response standard, terminate the application of the hose stream upon completion of the required duration of exposure or when failure occurs, whichever occurs first.




FIG. 4 Typical Hose Stream Pattern

8.4.4 After terminating the test, photograph both the exposed and unexposed sides of the test assembly.

9. Observations During the Hose Stream

9.1 Observe the unexposed surface of the test assembly during the application of the hose stream for the development of any hole, crack, or other penetration that allows the passage of water from the hose stream.

9.2 Observe any fully developed stream, wetting of the unexposed surface, water rolling down the unexposed surface, or water projected beyond the unexposed surface.

10. Report

10.1 Report test conditions and observations as part of the fire endurance test report and as specified in the fire endurance test method.

10.1.1 Report observations from the unexposed side of the test assembly including the development of any hole, crack, or other penetration that allows the passage of water from the hose stream.

10.1.2 Report any fully developed stream, wetting of the unexposed surface, water rolling down the unexposed surface, or water projected beyond the unexposed surface.

10.1.3 Report observations of water projecting between the device or construction and the supporting construction or the test frame.

11. Keywords

11.1 building element; composite assembly; curtain wall; door; fire barrier; fire endurance; fire-resistive joint system; fire stop; floor; hose stream; impact force; masonry unit assembly; nozzle; thermal shock; wall; window

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).