



Designation: D 1835 – 03a

An American National Standard

Standard Specification for Liquefied Petroleum (LP) Gases¹

This standard is issued under the fixed designation D 1835; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers those products commonly referred to as liquefied petroleum gases, consisting of propane, propene (propylene), butane, and mixtures of these materials. Four basic types of liquefied petroleum gases are provided to cover the common use applications.

1.2 This specification is applicable to products intended for use as domestic, commercial and industrial heating, and engine fuels.

1.3 The values stated in SI units are to be regarded as the standard. The values given in parentheses are for information only.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

¹ This specification is under the jurisdiction of ASTM Committee D02 on Petroleum Products and Lubricants and is the direct responsibility of Subcommittee D02.H0 on Liquefied Petroleum Gas.

Current edition approved ~~May 10,~~ Nov. 1, 2003. Published ~~May~~ November 2003. Originally approved in 1961. Last previous edition approved in ~~1997~~ 2003 as D 1835-~~97~~03.

2. Referenced Documents

2.1 ASTM Standards:²

- D 1265 Practice for Sampling Liquefied Petroleum (LP) Gases (Manual Method)
- D 1267 Test Method for Gage Vapor Pressure of Liquefied Petroleum (LP) Gases (LP-Gas Method)
- D 1657 Test Method for Density or Relative Density of Light Hydrocarbons by Pressure-Thermohydrometer² Hydrometer
- D 1837 Test Method for Volatility of Liquefied Petroleum (LP) Gases
- D 1838 Test Method for Copper Strip Corrosion by Liquefied Petroleum (LP) Gases
- D 2158 Test Method for Residues in Liquefied Petroleum (LP) Gases
- D 2163 Test Method for Analysis of Liquefied Petroleum (LP) Gases and Propene Concentrates by Gas Chromatography
- D 2420 Test Method for Hydrogen Sulfide in Liquefied Petroleum (LP) Gases (Lead Acetate Method)
- D 2598 Practice for Calculation of Certain Physical Properties of Liquefied Petroleum (LP) Gases from Compositional Analysis
- D 2713 Test Method for Dryness of Propane (Valve Freeze Method)
- D 2784 Test Method for Sulfur in Liquefied Petroleum Gases (Oxy-Hydrogen Burner or Lamp)
- D 3700 Practice for Obtaining LPG Samples Using a Floating Piston Cylinder
- D 6667 Test Method for Determination of Total Sulfur in Gaseous Hydrocarbons and Liquefied Petroleum Gases by Ultraviolet Fluorescence

2.2 Other Document:

- GPA Standard 2140³⁻⁴

3. Terminology

3.1 Definitions:

- 3.1.1 *commercial butane*—a hydrocarbon product for use where low volatility is required.
- 3.1.2 *commercial PB mixtures*—mixtures of propane and butane for use where intermediate volatility is required.
- 3.1.3 *commercial propane*—a hydrocarbon product for use where high volatility is required. Commercial propane is suitable for certain low severity internal combustion engine applications.
- 3.1.4 *special-duty propane*—a high-quality product composed chiefly of propane, which exhibits superior antiknock characteristics when used as an internal combustion engine fuel.

4. Sampling

4.1 Proper sampling of liquefied gases is extremely important if the test results are to be significant. Obtain representative samples in accordance with Practice D 1265 or Practice D 3700.

5. Detailed Requirements

- 5.1 The four types of liquefied petroleum gases shall conform to the requirements prescribed in Table 1.

6. Keywords

- 6.1 butane; HD-5 propane; liquefied petroleum (LP) gases specifications; propane

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards*, Vol 05.01, volume information, refer to the standard's Document Summary page on the ASTM website.

Annual Book of ASTM Standards, Vol 05.02.

⁴ Available from Gas Processors Assn., 6526 E. 60th St., Tulsa, OK 74145. www.gasprocessors.com

TABLE 1 Detailed Requirements for Liquefied Petroleum Gases

| | Product Type | | | | ASTM Test Methods (see Section 2) |
|--------------------------------------------|--------------------|--------------------|------------------------|-----------------------------------|-----------------------------------|
| | Commercial Propane | Commercial Butane | Commercial PB Mixtures | Special-Duty Propane ^A | |
| Vapor pressure at 37.8°C (100°F), max, kPa | 1434 | 483 | <i>B</i> | 1434 | D 1267 or D 2598 ^C |
| psig | 208 | 70 | <i>B</i> | 208 | D 1267 or D 2598 ^C |
| Volatile residue: | | | | | |
| — evaporated temperature, 95 %, max, °C | —38.3 | 2.2 | 2.2 | —38.3 | |
| evaporated temperature, 95 %, max, °C | —38.3 | 2.2 | 2.2 | —38.3 | |
| °F | —37 | 36 | 36 | —37 | D 1837 |
| — or | | | | | |
| or | | | | | |
| — butane and heavier, max, vol % | —2.5 | —... | —... | —2.5 | —D 2163 |
| butane and heavier, max, vol % | 2.5 | ... | ... | 2.5 | D 2163 |
| — pentane and heavier, max, vol % | —... | —2.0 | —2.0 | —... | —D 2163 |
| pentane and heavier, max, vol % | ... | 2.0 | 2.0 | ... | D 2163 |
| Propylene content, max, vol % | —... | —... | —... | —5.0 | —D 2163 |
| Propylene content, max, vol % | ... | ... | ... | 5.0 | D 2163 |
| Residual matter: | | | | | |
| — residue on evaporation 100 mL, max, mL | —0.05 | —0.05 | —0.05 | —0.05 | —D 2158 |
| residue on evaporation 100 mL, max, mL | 0.05 | 0.05 | 0.05 | 0.05 | D 2158 |
| — oil stain observation | —pass ^D | —pass ^D | —pass ^D | —pass ^D | —D 2158 |
| oil stain observation | pass ^D | pass ^D | pass ^D | pass ^D | D 2158 |
| Relative density at 15.6/15.6°C (60/60°F) | — <i>E</i> | — <i>E</i> | — <i>E</i> | —... | —D 1657 or D 2598 |
| Relative density at 15.6/15.6°C (60/60°F) | <i>E</i> | <i>E</i> | <i>E</i> | ... | D 1657 or D 2598 |
| Corrosion, copper, strip | —No. 4 | —No. 4 | —No. 4 | —No. 4 | —D 1838 ^F |
| Corrosion, copper, strip | No. 1 | No. 1 | No. 1 | No. 1 | D 1838 ^F |
| Sulfur, ppmw | —185 ^G | —140 ^G | —140 ^G | —123 ^G | —D 2784 |
| Sulfur, ppmw | 185 ^G | 140 ^G | 140 ^G | 123 ^G | D 2784 or D 6667 |
| Hydrogen sulfide | —pass | —pass | —pass | —pass | —D 2420 |
| Hydrogen sulfide | pass | pass | pass | pass | D 2420 |
| Moisture content | —pass ^H | —... | —... | —pass ^H | —D 2713 |
| Moisture content | pass | ... | ... | pass | D 2713 |
| Free water content | —... | —none ^I | —none ^I | —... | —... |
| Free water content | ... | none ^I | none ^I | ... | ... |

^A Equivalent to Propane HD-5 of GPA Standard 2140.

^B The permissible vapor pressures of products classified as PB mixtures shall not exceed 208 psig (1430 kPa) and additionally shall not exceed that calculated from the following relationship between the observed vapor pressure and the observed relative density:

$$\text{Vapor pressure, max} = 1167 - 1880 (\text{relative density at } 60/60^\circ\text{F}) \text{ or } 1167 - 1880 (\text{relative density at } 15.6/15.6^\circ\text{C})$$

A specific mixture shall be designated by the vapor pressure at 100°F in pounds per square inch gage. To comply with the designation, the vapor pressure of the mixture shall be within +0 to -10 psi of the vapor pressure specified.

^C In case of dispute about the vapor pressure of a product, the value actually determined by Test Method D 1267 shall prevail over the value calculated by Practice D 2598.

^D An acceptable product shall not yield a persistent oil ring when 0.3 mL of solvent residue mixture is added to a filter paper, in 0.1-mL increments and examined in daylight after 2 min as described in Test Method D 2158.

^E Although not a specific requirement, the relative density must be determined for other purposes and should be reported. Additionally, the relative density of PB mixture is needed to establish the permissible maximum vapor pressure (see Footnote B).

^F This method may not accurately determine the presence of reactive materials (for example, H₂S, S^o) in liquefied petroleum gas if the product contains corrosion inhibitors or other chemicals which diminish the reaction with the copper strip.

^G The total sulfur limits in these specifications *do include* sulfur compounds used for stenching purposes.

^H Commercial propane and Special duty propane should be produced to comply with the moisture content requirement, and de-icer additives should not routinely be used to pass dryness test requirements. That is, these products must be so dry that they are sub-saturated with water at most ambient temperatures. They should be maintained dry during storage and distribution. A de-icer such as methyl alcohol (methanol) should not be added to these products without specific agreement and approval of the purchaser. During short-term upsets in production, or inadvertent contamination by trace water during storage or distribution, addition of 50 ppm methyl alcohol has proven to be acceptable to prevent valve freezing in normal applications. For guidance, based on historical experience and phase separation data, the maximum cumulative addition of methyl alcohol should not exceed 200 ppm by volume.

^I The presence or absence of water shall be determined by visual inspection of the samples on which the relative density is determined.

APPENDIX

(Nonmandatory Information)

XI. SIGNIFICANCE OF ASTM SPECIFICATIONS FOR LIQUEFIED PETROLEUM (LP) GASES**XI.1 General**

XI.1.1 Liquefied petroleum gas products are composed of those readily liquefiable hydrocarbon compounds that are produced in the course of processing natural gas and also in the course of the conventional refining of crude oil. The composition of liquefied gases can vary widely depending upon the source and the nature of the treatment to which the products have been subjected.

XI.1.2 There are many uses for liquefied petroleum gases. Important uses include, (1) as domestic, commercial, and industrial fuels, (2) as a carbon source material in metal treating operations, (3) as refinery raw materials for synthesis of gasoline components, and (4) as petrochemical raw materials. The nature of the needs dictates the required composition characteristics in these various applications. Since the last three uses of those listed are in the category of specialty applications, which involve special requirements, they are excluded from consideration in the specifications.

XI.1.3 In substance, this specification is designed to properly define acceptable products for domestic, commercial, and industrial uses. In many cases it will be found that products meeting the specifications will also be usable in applications other than the ones for which they were designed. The following can be accepted as a general guide in the more common use applications of the four types of fuels:

XI.1.3.1 *Commercial Propane*—This fuel type is adequate for domestic, commercial, and industrial use, particularly in geographical areas and in seasons where low ambient temperatures are common, and where uniformity of fuel is an important consideration. Commercial propane is suitable for certain low severity internal combustion engine applications.

XI.1.3.2 *Commercial PB Mixtures*—This fuel type, since it covers a broad range of mixtures, permits the tailoring of fuels to specific needs. The various mixtures find application as domestic, commercial, and industrial fuel in areas and at times when low ambient temperature conditions are not encountered. This fuel type is not suitable for vapor withdrawal applications in cool or cold climates.

XI.1.3.3 *Commercial Butane*—This fuel type finds limited application as a domestic fuel in areas of warmer climates. It is similarly used in industrial applications where problems of fuel vaporization are not present, such as direct liquid injection.

XI.1.3.4 *Special-Duty Propane*—This fuel type, equivalent to HD-5 propane, is a product tailored to meet the restrictive needs of internal combustion engines operating under moderate to high engine severity. Fuel products of this type will be less variable in composition and combustion characteristics than the other products covered by this specification.

XI.2 Significance and Use

XI.2.1 This specification addresses commercial liquefied petroleum gases consisting of either propane or butane or mixtures thereof. Consequently, the important characteristics of these products can be defined and controlled by a relatively few simple measurements. The specification test methods provided achieve the desired results. The significance of the various tests as they can apply to consumer problems is summarized here.

XI.2.2 Vapor Pressure, Volatility, and Relative Density:

XI.2.2.1 *Vapor Pressure*—Indirect measure of the most extreme low-temperature conditions under which initial vaporization can be expected to take place. It can be considered as a semiquantitative measure of the amount of the most volatile material present in the product. It can also be used as a means for predicting the maximum pressures which may be experienced at fuel tank temperatures. Vapor pressure becomes more significant when it is related to volatility.

XI.2.2.2 *Volatility*—Expressed in terms of the 95 % evaporated temperature of the product, is a measure of the amount of least volatile fuel component present in the product. Coupled with a vapor pressure limit, it serves to assure essentially single-component products in the cases of commercial propane and commercial butane fuel types. When volatility is coupled with a vapor pressure limit which has been related to gravity, as in the case of the commercial PB-mixture type of fuels, the combination serves to assure essentially two component mixtures for such fuels. When coupled with a proper vapor pressure limit, this measurement serves to assure that special-duty propane products will be composed chiefly of propane and propylene and that propane will be the major constituent.

XI.2.2.3 *Relative Density*—By itself, has little significance. It becomes of value only when related to vapor pressure and volatility. Since relative density is of importance in meeting transportation and storage requirements it is always determined for all liquefied petroleum gas products.

XI.2.3 *Other Product Characteristics* —While the vaporization and combustion characteristics of commercial liquefied gas products are completely defined for the normal use applications by vapor pressure, volatility, and relative density, as given in XI.2.2, there are other items which either affect or might affect the results obtained in some specific use applications. For that reason, limits are specified for residue content, copper corrosion, sulfur content, moisture content, and free water content to provide assurance of product dependability under the more extreme conditions of use.

XI.2.3.1 *Residue*—A measure of the concentration of soluble hydrocarbon materials present in the product which are substantially less volatile than the liquefied petroleum gas product being sampled. Control of residue content is of importance in

applications where the fuel is used in liquid or vapor feed systems (where fuel vapors are withdrawn from the top of the LPG storage container). In either case, failure to limit the permissible concentration of residue materials may result in troublesome deposits or regulating equipment may become fouled, or both.

X1.2.3.2 *Copper Corrosion*—Limits are for the purpose of providing assurance that difficulties will not be experienced in the deterioration of the copper and copper-alloy fittings and connections which are commonly used in many types of utilization, storage, and transportation equipment. The copper corrosion test will detect the presence of hydrogen sulfide, which is highly toxic. The copper corrosion limits also provide assurance that the LP-Gas will not contain H₂S in such quantities as to present a health and safety hazard if it is known that the product does not contain corrosion inhibitors or other chemicals which diminish the reaction with the copper strip. In addition, Test Method D 2420 is recommended as a field test and added safeguard to ensure that LP-Gas does not contain detectable amounts of hydrogen sulfide.

X1.2.3.3 *Sulfur Content*—Limits are provided to more completely define liquefied petroleum gas products because these products are generally lower in sulfur content than most other petroleum-derived fuels. The limit on sulfur content minimizes sulfur oxide emissions and limits potential corrosion by exhaust gases from combustion of LPG.

X1.2.3.4 *Moisture Content*—Limits the percent saturation of the product with water. This measurement is a requirement only on the commercial and special duty propane types of liquefied petroleum gas which must be sub-saturated with water at temperatures above about -26 °C. The purpose of moisture content control is to provide assurance that pressure reducing regulators and similar equipment will operate consistently without troublesome freeze-ups caused by the separation of dissolved water from the product. The presence of an antifreeze agent such as methyl alcohol which prevents separated water from freezing may allow use of propane containing excessive dissolved water in many applications.

NOTE X1.1—Commercial propane and special duty propane should be produced to comply with the moisture content requirement, and de-icer additives should not routinely be used to pass dryness test requirements. That is, these products must be so dry that they are sub-saturated with water at most ambient temperatures. They should be maintained dry during storage and distribution. A de-icer such as methyl alcohol (methanol) should not be added to these products without specific agreement and approval of the purchaser. During short-term upsets in production, or inadvertent contamination by trace water during storage or distribution, addition of 50 ppm methyl alcohol has proven to be acceptable to prevent valve freezing in normal applications. For guidance, based on historical experience and phase separation data, the maximum cumulative addition of methyl alcohol should not exceed 200 ppm by volume.

X1.2.3.5 *Free Water Content*—Of importance only on the commercial PB-mixtures and commercial butane type products. These two types of products are normally used under ambient conditions which are mild and, as a consequence, the only requirement is vigilance to ensure that no free water is present.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).