

Designation: D 853 – 97 (Reapproved 2001)

Standard Test Method for Hydrogen Sulfide and Sulfur Dioxide Content (Qualitative) of Industrial Aromatic Hydrocarbons¹

This standard is issued under the fixed designation D 853; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This test method covers the determination of the hydrogen sulfide and sulfur dioxide content (qualitative) of industrial aromatic hydrocarbons.

1.2 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use. For specific hazard statements see Section 6.

2. Referenced Documents

2.1 ASTM Standards:

- D 850 Test Method for Distillation of Industrial Aromatic Hydrocarbons and Related Materials²
- D 3437 Practice for Sampling and Handling Liquid Cyclic Products²
- D 4790 Terminology of Aromatic Hydrocarbons and Related Chemicals²
- 2.2 Other Documents:
- OSHA Regulations, 29 CFR, Paragraphs 1910.1000 and 1910.1200³

3. Terminology

3.1 See Terminology D 4790 for Definition of terms used in this test method.

4. Summary of Test Method

4.1 This test method involves a qualitative color test for H_2S and SO_2 that utilizes filter paper containing lead acetate and starch paper containing potassium iodate. The test is performed when carrying out the Test Method D 850 distillation test.

5. Significance and Use

5.1 This test method is suitable for setting specifications on industrial aromatic hydrocarbons and related materials and for use as an internal quality control tool.

5.2 This test method is a qualitative one for hydrogen sulfide (H_2S) and sulfur dioxide (SO_2). It should not be considered quantitative. It gives an indication of the presence of H_2S or SO_2 , or both, which may cause objectionable odors or be corrosive to certain materials of construction.

6. Reagents

6.1 Lead Acetate Solution (saturated).

6.2 *Potassium Iodate Solution* (100 g/L)—Dissolve 10 g of potassium iodate (KIO₃) in water and dilute to 100 mL.

6.3 *Starch Paper*—Dip strips of filter paper in starch solution and dry.

7. Hazards

7.1 Consult current OSHA regulations, supplier's Material Safety Data Sheets, and local regulations for all materials used in this test method.

8. Sampling

8.1 Sampling should follow safe rules in order to adhere to all safety precautions as outlined in the latest OSHA regulations. Refer to Practice D 3437 for sampling and handling of aromatic hydrocarbons analyzed by this test method.

9. Procedure

9.1 Make a qualitative test for H_2S and SO_2 , at the time of performing the distillation test, see Test Method D 850. This is done by hanging a strip of filter paper moistened with the lead acetate solution and a strip of starch paper moistened with the potassium iodate solution on the end of the condenser tube. The strips are placed so that they are suspended in the upper part of the receiving cylinder so that drops of condensate pass between the strips without touching them. If, at the end of the test, the lead acetate paper shows discoloration, H_2S is present but not SO_2 . If the lead acetate paper shows no discoloration but the starch iodate paper develops a blue color, SO_2 is present

Copyright © ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States.

¹This test method is under the jurisdiction of ASTM Committee D16 on Aromatic Hydrocarbons and Related Chemicals and is the direct responsibility of Subcommittee D16.01 on Benzene, Toluene, Xylenes, Cyclohexane, and Their Derivatives.

Current edition approved June 10, 1997. Published September 1997. Originally published as D 853 - 45 T. Last previous edition D 853 - 91.

² Annual Book of ASTM Standards, Vol 06.04.

³ Available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

NOTICE: This standard has either been superceded and replaced by a new version or discontinued. Contact ASTM International (www.astm.org) for the latest information.

∰ D 853

but not H_2S . If neither paper shows discoloration, neither H_2S nor SO_2 is present.

11. Keywords

11.1 hydrogen sulfide; sulfur dioxide

10. Precision and Bias

10.1 In the case of pass/fail data, no generally accepted method for determining precision and bias is currently available.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).